

**WAC 296-307-45520 Fire protection in the vapor area.** The employer must provide a manual fire extinguisher near the tank that is suitable for putting out flammable and combustible liquid fires.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-45520, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-45520, filed 5/6/03, effective 8/1/03.]