

- WAC 296-826-40050 Other refrigerated storage equipment.** (1) You must discharge ammonia to storage by using either:
- (a) A receiver with an automatic float valve; or
 - (b) A high pressure liquid drain trap of suitable capacity.
- (2) You must make sure receivers are:
- (a) Designed for at least 250 psig; and
 - (b) Equipped with all of the following:
 - (i) Necessary connections;
 - (ii) Safety relief valves;
 - (iii) Gauging devices.
- (3) You must cover insulated containers and pipelines with material that meets all of the following:
- (a) Thick enough for the temperatures it will be exposed to;
 - (b) Supported;
 - (c) Weather and fire resistant.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-826-40050, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 06-10-067, § 296-826-40050, filed 5/2/06, effective 9/1/06.]