

(Effective July 1, 2023)

WAC 51-50-1110 Section 1110—Other features and facilities.

1110.2 Toilet and bathing facilities. Each toilet room and bathing room shall be accessible. Where a floor level is not required to be connected by an accessible route, the only toilet rooms or bathing rooms provided within the facility shall not be located on the inaccessible floor. Except as provided for in Sections 1110.2.4 and 1110.2.5 at least one of each type of fixture, element, control or dispenser in each accessible toilet room and bathing room shall be accessible.

- EXCEPTIONS:
1. Toilet rooms or bathing rooms accessed only through a private office, not for common or public use and intended for use by a single occupant, shall be permitted to comply with the specific exceptions in ICC A117.1.
 2. This section is not applicable to toilet and bathing rooms that serve dwelling units or sleeping units that are not required to be accessible by Section 1108.
 3. Where multiple single-user all-gender toilet rooms or bathing rooms are clustered at a single location, at least 50 percent shall be accessible.
 4. Where no more than one urinal is provided in a toilet room or bathing room, the urinal is not required to be accessible.
 5. Toilet rooms or bathing rooms that are part of critical care or intensive care patient sleeping rooms serving accessible units are not required to be accessible.
 6. Toilet rooms or bathing rooms designed for bariatrics patients are not required to comply with the toilet room and bathing room requirement in ICC A117.1. The sleeping units served by bariatrics toilet or bathing rooms shall not count toward the required number of accessible sleeping units.
 7. Where permitted in Section 1107, in toilet rooms or bathrooms serving accessible units, water closets designed for assisted toileting shall be permitted to comply with Section 1109.2.4.
 8. Where permitted in Section 1107, in bathrooms serving accessible units, showers designed for assisted toileting shall be permitted to comply with Section 1109.2.5.
 9. Where toilet facilities are primarily for children's use, required accessible water closets, toilet compartments and lavatories shall be permitted to comply with children's provision of ICC A117.1.

1110.5.1 Minimum number. Not fewer than two drinking fountains shall be provided. One drinking fountain shall comply with the requirements for people who use a wheelchair and one drinking fountain shall comply with the requirements for standing persons.

- EXCEPTIONS:
1. A single drinking fountain with two separate spouts that complies with the requirements for people who use a wheelchair and standing persons shall be permitted to be substituted for two separate drinking fountains.
 2. Where drinking fountains are primarily for children's use, drinking fountains for people using wheelchairs shall be permitted to comply with the children's provisions in ICC A117.1 and drinking fountains for standing children shall be permitted to provide the spout at 30 inches (762 mm) minimum above the floor.
 3. In all occupancies that require more than two drinking fountains per floor or secured area, bottle filling stations shall be allowed to be substituted in accordance with Section 2902.5.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-1110, filed 6/14/22, effective 7/1/23.]