

***(Effective until July 1, 2023)***

**WAC 51-50-3304 Section 3304—Site work.**

**3304.2 Fire watch during construction.** Where required by the fire code official, a fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12,192 mm) in height above the lowest adjacent grade.

EXCEPTIONS:     1. New construction that is built under the IRC.  
                  2. New construction less than 5 stories and 50,000 square feet per story.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 21-06-035, § 51-50-3304, filed 2/23/21, effective 3/26/21; WSR 20-01-090, § 51-50-3304, filed 12/12/19, effective 7/1/20.]

***(Effective July 1, 2023)***

**WAC 51-50-3304 Reserved.**

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-3304, filed 6/14/22, effective 7/1/23; WSR 21-06-035, § 51-50-3304, filed 2/23/21, effective 3/26/21; WSR 20-01-090, § 51-50-3304, filed 12/12/19, effective 7/1/20.]