

(Effective July 1, 2023)

WAC 51-54A-0321 Artificial combustible vegetation.

321.1 Artificial combustible vegetation on roofs and near buildings. Artificial combustible vegetation exceeding 6 feet (1829 mm) in height and permanently installed outdoors within 5 feet (1524 mm) of a building or on the roof of a building shall comply with Section 807.4.1. The placement of artificial combustible vegetation shall also comply with Sections 806.3 and 807.4.2.

EXCEPTIONS: 1. Artificial decorative vegetation located more than 30 feet (9144 mm) from the exterior wall of a building.
 2. Artificial decorative vegetation used at structures regulated by the International Residential Code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-0321, filed 6/14/22, effective 7/1/23.]