

WAC 246-215-05215 Design, construction and installation—Back-flow prevention, air gap (FDA Food Code 5-202.13). An air gap between the DRINKING WATER supply inlet and the flood level rim of the PLUMBING FIXTURES or EQUIPMENT, meet the definition of an APPROVED air gap in WAC 246-290-010.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05215, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05215, filed 1/17/13, effective 5/1/13.]