

**WAC 246-274-405 Location.** Tier 1, Tier 2, and Tier 3 greywater irrigation systems shall be designed and installed to meet the minimum horizontal setback requirements specified in Table I.

**Table I  
Minimum Horizontal Setbacks**

	<b>From edge of subsurface irrigation components</b>	<b>From tank and other system components</b>
Building foundations		
Down-gradient <sup>1</sup> :	10 ft.	N/A
Up-gradient:	2 ft.	N/A
Property or easement line	2 ft.	2 ft.
Pressurized water supply line/ public water main	10 ft.	10 ft.
Interceptor/ curtain drains/drainage ditches		
Down-gradient:	30 ft.	N/A
Up-gradient:	10 ft.	N/A
In-ground swimming pool	10 ft.	5 ft.
Spring or surface water measured from the ordinary high-water mark <sup>2</sup>	100 ft.	50 ft.
Well or suction line	100 ft.	50 ft.
Public drinking water well	100 ft.	100 ft.
Public drinking water spring measured from the ordinary high-water mark	200 ft.	200 ft.
Decommissioned well (decommissioned in accordance with chapter 173-160 WAC)	10 ft.	N/A
Down-gradient cuts or banks with at least 5 ft. of original, undisturbed soil above a restrictive layer due to a structural or textural change	25 ft.	N/A
Down-gradient cuts or banks with less than 5 ft. of original, undisturbed soil above a restrictive layer due to a structural or textural change	50 ft.	N/A
On-site sewage system primary and reserve areas	10 ft.	N/A

<sup>1</sup> The item is down-gradient when liquid will flow toward it upon encountering a water table or a restrictive layer. The item is up-gradient when liquid will flow away from it upon encountering a water table or restrictive layer.

<sup>2</sup> If surface water is used as a public drinking water supply, the greywater system must be located outside of the required source water protection area.

[Statutory Authority: RCW 90.46.015. WSR 11-02-011, § 246-274-405, filed 12/28/10, effective 7/31/11.]