

WAC 296-150V-1090 What are the standards for equipment and installations? The manufacturer's equipment and installation specifications must be followed. Other approved standards are acceptable when:

- Installed according to the manufacturer's installation instructions; and
- Approved by a listing or testing agency.

Note: Gas furnaces, gas water heaters, and gas refrigerators must be sealed combustion or completely separated from the interior of the conversion vendor unit or medical unit.

[Statutory Authority: RCW 43.22.340, 43.22.400, 43.22.432, 43.22.433, 43.22.434, 43.22.480, and 43.22.485, 2002 c 268, and chapter 43.22 RCW. WSR 03-12-044, § 296-150V-1090, filed 5/30/03, effective 6/30/03. Statutory Authority: Chapter 43.22 RCW. WSR 99-18-069, § 296-150V-1090, filed 8/31/99, effective 10/1/99.]