

**WAC 296-307-41005 Definitions that apply to this part. Adequate ventilation** (for fire prevention during normal operation). The concentration of the gas in a gas-air mixture does not exceed 25% of the lower flammable limit.

**Containers.** All vessels, such as tanks, cylinders, or drums, used to transport or store LP-gases.

**DOT.** The federal Department of Transportation.

**DOT container.** A container that meets DOT regulations.

**DOT cylinder.** A cylinder that meets DOT regulations.

**DOT regulations/requirements/specifications.** The DOT regulations of 49 C.F.R. Part 178.

**Liquefied petroleum gases and LP-gas.** Any material that is composed mostly of any of the following: Hydrocarbons, or mixtures of them; propane; propylene; butanes (normal butane or iso-butane); and butylenes.

**PSIA.** Pounds per square inch absolute.

**PSIG.** Pounds per square inch gauge.

**Systems.** An assembly of the container or containers, major devices such as vaporizers, safety-relief valves, excess flow valves, regulators, and piping connecting such parts.

**Vaporizer-burner.** An integral vaporizer-burner unit, dependent upon the heat generated by the burner to vaporize the liquid used for dehydrators or dryers.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-41005, filed 10/20/20, effective 11/20/20. WSR 97-09-013, recodified as § 296-307-41005, filed 4/7/97, effective 4/7/97. Statutory Authority: RCW 49.17.040, [49.17.]050 and [49.17.]060. WSR 96-22-048, § 296-306A-41005, filed 10/31/96, effective 12/1/96.]