

WAC 296-806-42502 Provide locks on chamber doors of large air conditioning units. You must make sure all door locks on air conditioning unit chambers, that are large enough for employees to enter, can be operated from both inside and outside the chamber.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 15-24-102, § 296-806-42502, filed 12/1/15, effective 1/5/16; WSR 04-14-028, § 296-806-42502, filed 6/29/04, effective 1/1/05.]