

WAC 296-835-12020 Provide fire protection in the vapor area.

You must provide a manual fire extinguisher near the tank that is suitable for putting out fires involving flammable liquids and liquids with flashpoints greater than 199.4°F (93°C).

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-835-12020, filed 9/5/17, effective 10/6/17. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060 and 29 C.F.R. 1910 Subpart Z. WSR 14-07-086, § 296-835-12020, filed 3/18/14, effective 5/1/14. Statutory Authority: RCW 49.17.010, [49.17].040, and [49.17].050. WSR 02-15-102, § 296-835-12020, filed 7/17/02, effective 10/1/02.]