

WAC 480-90-333 Initial accuracy of meters. (1) Each meter must be in good mechanical shape and adjusted to read as accurately as practical before being placed in service. Meters are required to be free of leaks and deliver gas without noticeable fluctuation due to mechanical operation of the meter.

(2) The gas utility must seal all meters in service or use a sealing method acceptable to the commission.

[Statutory Authority: RCW 80.01.040 and 80.04.160. WSR 01-11-003 (Docket No. UG-990294, General Order No. R-484), § 480-90-333, filed 5/3/01, effective 6/3/01.]