

**(Effective until March 15, 2024)**

**WAC 51-50-10240 Section 1024—Exit passageways.**

**1024.9 Exit passageway exterior walls.** Exterior walls of the exit passageway shall comply with Section 705. Where nonrated walls or unprotected openings enclose the exterior of the exit passageway and the walls or openings are exposed by other parts of the building at an angle of less than 180 degrees (3.14 rad), the building exterior walls within 10 feet (3048 mm) horizontally of a nonrated wall or unprotected opening shall have a *fire-resistance rating* of not less than 1 hour. Openings within such exterior walls shall be protected by opening protectives having a *fire-protection rating* of not less than 3/4 hour. This construction shall extend vertically from the ground to a point 10 feet (3048 mm) above the floor of the exit passageway, or to the roof line, whichever is lower.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-21-021, § 51-50-10240, filed 10/9/20, effective 11/9/20; WSR 20-01-090, § 51-50-10240, filed 12/12/19, effective 7/1/20.]

**(Effective March 15, 2024)**

**WAC 51-50-10240 Reserved.**

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-10240, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 20-21-021, § 51-50-10240, filed 10/9/20, effective 11/9/20; WSR 20-01-090, § 51-50-10240, filed 12/12/19, effective 7/1/20.]