

**(Effective until March 15, 2024)**

**WAC 51-50-1101 Section 1101—General.**

**1101.2 Design.** Buildings and facilities shall be designed and constructed to be accessible in accordance with this code and ICC A117.1, except those portions of ICC A117.1 amended by this section.

**1101.2.1 (ICC A117.1 Section 403.5) Clear width of accessible route.** Clear width of an accessible route shall comply with ICC A117.1 Section 403.5. For exterior routes of travel, the minimum clear width shall be 44 inches (1118 mm).

**1101.2.2 (ICC A117.1 Section 404.2.8) Door-opening force.** Fire doors shall have the minimum opening force allowable by the appropriate administrative authority. The force for pushing or pulling open doors other than fire doors shall be as follows:

1. Interior hinged door: 5.0 pounds (22.2 N) maximum
2. Interior sliding or folding doors: 5.0 pounds (22.2 N) maximum
3. Exterior hinged, sliding or folding door: 10 pounds (44.4 N)

maximum.

EXCEPTION: Interior or exterior automatic doors complying with Section 404.3 of ICC ANSI A117.1.

These forces do not apply to the force required to retract latch bolts or disengage other devices that hold the door in a closed position.

**1101.2.3 (ICC A117.1 Section 407.4.6.2.2) Arrangement of elevator car buttons.** Buttons shall be arranged with numbers in ascending order. When two or more columns of buttons are provided they shall read from left to right.

**1101.2.4 (ICC ANSI A117.1 606.7) Operable parts.** Operable parts on drying equipment, towel or cleansing product dispensers, and disposal fixtures shall comply with Table 603.6.

**1101.2.5 (ICC A117.1 Section 604.6) Flush controls.** Flush controls shall be hand operated or automatic. Hand operated flush controls shall comply with Section 309, except the maximum height above the floor shall be 44 inches. Flush controls shall be located on the open side of the water closet.

EXCEPTION: In ambulatory accessible compartments complying with Section 604.10, flush controls shall be permitted to be located on either side of the water closet.

**1101.2.6 (ICC A117.1 Section 703.6.3.1) International Symbol of Accessibility.** Where the International Symbol of Accessibility is required, it shall be proportioned complying with ICC A117.1 Figure 703.6.3.1. All interior and exterior signs depicting the International Symbol of Accessibility shall be white on a blue background.

**1101.2.7 (ICC A117.1 Section 502.2) Vehicle space size.** Car and van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.8 (ICC A117.1 Section 502.4.2) Access aisle width.** Access aisles serving car parking spaces shall be 60 inches (1525 mm) minimum in width. Access aisles serving van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.9 (ICC A117.1 Section 502.7) Identification.** Accessible parking spaces shall be indicated by a vertical sign. The signs shall include the International Symbol of Accessibility complying with section 703.6.3.1. Such symbol shall be white on a blue background. Signs

identifying van parking spaces shall contain the designation "van accessible." The sign may include additional language such as, but not limited to, an indication of the amount of the monetary penalty defined in RCW 46.19.050 for parking in the space without a valid permit. A vertical "no parking" sign shall be erected at the head of each access aisle located adjacent to an accessible parking space. The sign may include additional language such as, but not limited to, an indication of any penalty for parking in an access aisle. Such signs shall be 60 inches (1525 mm) minimum above the floor of the parking space, measured to the bottom of the sign.

[Statutory Authority: RCW 19.27.074 and 19.27.550. WSR 17-23-182, § 51-50-1101, filed 11/21/17, effective 7/1/18. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-064, § 51-50-1101, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-1101, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-1101, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074, and chapters 19.27 and 34.05 RCW. WSR 05-24-070, § 51-50-1101, filed 12/5/05, effective 7/1/06; WSR 05-01-014, § 51-50-1101, filed 12/2/04, effective 7/1/05. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-108, § 51-50-1101, filed 12/17/03, effective 7/1/04.]

**(Effective March 15, 2024)**

**WAC 51-50-1101 Section 1101—General.**

**1101.2 Design.** Buildings and facilities shall be designed and constructed to be accessible in accordance with this code and ICC A117.1, except those portions of ICC A117.1 amended by this section.

**1101.2.2 (ICC A117.1 Section 404.2.8) Door-opening force.** Fire doors and doors or gates required to be equipped with panic hardware, break away features or other factors requiring higher opening force for safety reasons shall have the minimum opening force allowable in scoping provisions adopted by the appropriate administrative authority. For other doors or gates, the force for pushing or pulling open doors or gates shall be as follows:

1. Interior hinged door: 5.0 pounds (22.2 N) maximum
2. Interior sliding or folding doors: 5.0 pounds (22.2 N) maximum
3. Exterior hinged, sliding or folding door: 10 pounds (44.4 N)

maximum.

EXCEPTION: The force required to retract latch bolts or disengage other devices that hold the door or gate in a closed position shall not apply to panic hardware, delayed egress devices or fire-rated hardware.

**1101.2.4 (ICC ANSI A117.1 603.6) Operable parts.** Operable parts on drying equipment, towel or cleansing product dispensers, and disposal fixtures shall comply with Table 603.6.

**1101.2.5 (ICC A117.1 Section 604.6) Flush controls.** Flush controls shall be hand operated or automatic. Hand operated flush controls shall comply with Section 309, except the maximum height above the floor shall be 44 inches. Flush controls shall be located on the open side of the water closet.

EXCEPTION: In ambulatory accessible compartments complying with Section 604.10, flush controls shall be permitted to be located on either side of the water closet.

**1101.2.6 (ICC A117.1 Section 703.6.3.1) International Symbol of Accessibility.** Where the International Symbol of Accessibility is required, it shall be proportioned complying with ICC A117.1 Figure 703.6.3.1. All interior and exterior signs depicting the International Symbol of Accessibility shall be white on a blue background.

**1101.2.7 (ICC A117.1 Section 502.2) Vehicle space size.** Car and van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.8 (ICC A117.1 Section 502.4.2) Access aisle width.** Access aisles serving car parking spaces shall be 60 inches (1525 mm) minimum in width. Access aisles serving van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.9 (ICC A117.1 Section 502.7) Identification.** Accessible parking spaces shall be indicated by a vertical sign. The signs shall include the International Symbol of Accessibility complying with section 703.6.3.1. Such symbol shall be white on a blue background. Signs identifying van parking spaces shall contain the designation "van accessible." The sign may include additional language such as, but not limited to, an indication of the amount of the monetary penalty defined in RCW 46.19.050 for parking in the space without a valid permit. A vertical "no parking" sign shall be erected at the head of each access aisle located adjacent to an accessible parking space. The sign may include additional language such as, but not limited to, an indication of any penalty for parking in an access aisle. Such signs shall be 60 inches (1525 mm) minimum above the floor of the parking space, measured to the bottom of the sign.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-1101, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.074 and 19.27.550. WSR 17-23-182, § 51-50-1101, filed 11/21/17, effective 7/1/18. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-064, § 51-50-1101, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-1101, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-1101, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074, and chapters 19.27 and 34.05 RCW. WSR 05-24-070, § 51-50-1101, filed 12/5/05, effective 7/1/06; WSR 05-01-014, § 51-50-1101, filed 12/2/04, effective 7/1/05. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-108, § 51-50-1101, filed 12/17/03, effective 7/1/04.]

***(Effective March 16, 2024)***

**WAC 51-50-1101 Section 1101—General.**

**1101.2 Design.** Buildings and facilities shall be designed and constructed to be accessible in accordance with this code and ICC A117.1, except those portions of ICC A117.1 amended by this section.

**1101.2.1 Reserved.**

**1101.2.2 (ICC A117.1 Section 404.2.8) Door-opening force.** Fire doors and doors or gates required to be equipped with panic hardware, break away features or other factors requiring higher opening force for

safety reasons shall have the minimum opening force allowable in scoping provisions adopted by the appropriate administrative authority. For other doors or gates, the force for pushing or pulling open doors or gates shall be as follows:

1. Interior hinged door: 5.0 pounds (22.2 N) maximum
2. Interior sliding or folding doors: 5.0 pounds (22.2 N) maximum
3. Exterior hinged, sliding or folding door: 10 pounds (44.4 N) maximum.

EXCEPTION: The force required to retract latch bolts or disengage other devices that hold the door or gate in a closed position shall not apply to panic hardware, delayed egress devices or fire-rated hardware.

### **1101.2.3 Reserved.**

**1101.2.4 (ICC ANSI A117.1 603.6) Operable parts.** Operable parts on drying equipment, towel or cleansing product dispensers, and disposal fixtures shall comply with Table 603.6.

**1101.2.5 (ICC A117.1 Section 604.6) Flush controls.** Flush controls shall be hand operated or automatic. Hand operated flush controls shall comply with Section 309, except the maximum height above the floor shall be 44 inches. Flush controls shall be located on the open side of the water closet.

EXCEPTION: In ambulatory accessible compartments complying with Section 604.10, flush controls shall be permitted to be located on either side of the water closet.

**1101.2.6 (ICC A117.1 Section 703.6.3.1) International Symbol of Accessibility.** Where the International Symbol of Accessibility is required, it shall be proportioned complying with ICC A117.1 Figure 703.6.3.1. All interior and exterior signs depicting the International Symbol of Accessibility shall be white on a blue background.

**1101.2.7 (ICC A117.1 Section 502.2) Vehicle space size.** Car and van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.8 (ICC A117.1 Section 502.4.2) Access aisle width.** Access aisles serving car parking spaces shall be 60 inches (1525 mm) minimum in width. Access aisles serving van parking spaces shall be 96 inches (2440 mm) minimum in width.

**1101.2.9 (ICC A117.1 Section 502.7) Identification.** Accessible parking spaces shall be indicated by a vertical sign. The signs shall include the International Symbol of Accessibility complying with section 703.6.3.1. Such symbol shall be white on a blue background. Signs identifying van parking spaces shall contain the designation "van accessible." The sign may include additional language such as, but not limited to, an indication of the amount of the monetary penalty defined in RCW 46.19.050 for parking in the space without a valid permit. A vertical "no parking" sign shall be erected at the head of each access aisle located adjacent to an accessible parking space. The sign may include additional language such as, but not limited to, an indication of any penalty for parking in an access aisle. Such signs shall be 60 inches (1525 mm) minimum above the floor of the parking space, measured to the bottom of the sign.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-102, § 51-50-1101, filed 11/15/23, effective 3/16/24; WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-1101, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.074 and 19.27.550. WSR 17-23-182, § 51-50-1101, filed 11/21/17, effective 7/1/18. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR

16-03-064, § 51-50-1101, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-1101, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-1101, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074, and chapters 19.27 and 34.05 RCW. WSR 05-24-070, § 51-50-1101, filed 12/5/05, effective 7/1/06; WSR 05-01-014, § 51-50-1101, filed 12/2/04, effective 7/1/05. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 04-01-108, § 51-50-1101, filed 12/17/03, effective 7/1/04.]