

(Effective until March 15, 2024)

WAC 51-50-480809 Section 809—Plumbing.

809.1 Minimum fixtures. Where the occupant load of the story is increased by more than 20 percent, plumbing fixtures for the story shall be provided in quantities specified in the International Building Code based on the increased occupant load.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-21-021, § 51-50-480809, filed 10/9/20, effective 11/9/20.]

(Effective March 15, 2024)

WAC 51-50-480809 Section 809—Energy conservation.

809.1 Minimum requirements. Level 2 alterations to existing buildings or structures shall comply with the Washington State Energy Code (chapter 51-11C WAC).

[Statutory Authority: RCW 19.27.031, 19.27.074, and 19.27.540. WSR 23-02-073, 23-12-103, and 23-20-023, § 51-50-480809, filed 1/4/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-21-021, § 51-50-480809, filed 10/9/20, effective 11/9/20.]