

(Effective until March 15, 2024)

WAC 51-52-0403 Section 403—Mechanical ventilation.

403.1 Ventilation system. Mechanical ventilation shall be provided by a method of supply air and return or *exhaust air*. The amount of supply air shall be approximately equal to the amount of return and *exhaust air*. The system shall not be prohibited from producing negative or positive pressure. The system to convey ventilation air shall be designed and installed in accordance with Chapter 6.

403.2 Outdoor air required. The minimum *outdoor airflow rate* shall be determined in accordance with Section 403.3.

EXCEPTIONS:

1. Where the registered design professional demonstrates that an engineered ventilation system design will prevent the maximum concentration of contaminants from exceeding that obtainable by the rate of *outdoor air* ventilation determined in accordance with Section 403.3, the minimum required rate of *outdoor air* shall be reduced in accordance with such engineered system design.
2. Alternate systems designed in accordance with ASHRAE Standard 62.1 Section 6.2, Ventilation Rate Procedure, shall be permitted.

403.2.1 Recirculation of air. The air required by Section 403.3 shall not be recirculated. Air in excess of that required by Section 403.3 shall not be prohibited from being recirculated as a component of supply air to building spaces, except that:

1. Ventilation air shall not be recirculated from one dwelling to another or to dissimilar occupancies.

2. Supply air to a swimming pool and associated deck areas shall not be recirculated unless such air is dehumidified to maintain the relative humidity of the area at 60 percent or less. Air from this area shall not be recirculated to other spaces where 10 percent or more of the resulting supply airstream consists of air recirculated from these spaces.

3. Where mechanical exhaust is required by Note b in Table 403.3.1.1, recirculation of air from such spaces shall be prohibited. All air supplied to such spaces shall be exhausted, including any air in excess of that required by Table 403.3.1.1.

4. Where mechanical exhaust is required by Note g in Table 403.3.1.1, mechanical exhaust is required and recirculation from such spaces is prohibited where more than 10 percent of the resulting supply airstream consists of air recirculated from these spaces. Return air from such spaces shall only be permitted to be recirculated when returned to an energy recovery ventilation system complying with Section 514. Recirculation of air that is contained completely within such spaces shall not be prohibited.

403.3 Outdoor air and local exhaust airflow rates. Group R occupancies shall be provided with outdoor air and local exhaust in accordance with Section 403.4. All other buildings intended to be occupied shall be provided with outdoor air and local exhaust in accordance with Section 403.3.1.

403.3.1.1 Outdoor airflow rate. Ventilation systems shall be designed to have the capacity to supply the minimum outdoor airflow rate determined in accordance with this section. In each occupiable space, the ventilation system shall be designed to deliver the required rate of outdoor airflow to the breathing zone. Outdoor air shall be supplied directly to each occupiable space from an air handling unit through a fully ducted path or ducted to within 12 inches of the return air opening of a fan-powered terminal unit used to transfer the outdoor air to the occupiable space. The occupant load utilized for design of the ventilation system shall not be less than the number determined from the estimated maximum occupant load rate indicated in Table

403.3.1.1. Ventilation rates for occupancies not represented in Table 403.3.1.1 shall be those for a listed occupancy classification that is most similar in terms of occupant density, activities and building construction; or shall be determined by an approved engineering analysis. The ventilation system, including transfer fan-powered terminal units shall be designed to supply the required rate of ventilation air continuously during the period the building is occupied, except as otherwise stated in other provisions of the code.

With the exception of smoking lounges, the ventilation rates in Table 403.3.1.1 are based on the absence of smoking in occupiable spaces. Where smoking is anticipated in a space other than a smoking lounge, the ventilation system serving the space shall be designed to provide ventilation over and above that required by Table 403.3.1.1 in accordance with accepted engineering practice.

EXCEPTION: Where occupancy density is known and documented in the plans, the outside air rate may be based on the design occupant density. Under no circumstance shall the occupancies used result in outside air less than one-half that resulting from application of Table 403.3.1.1 estimated maximum occupancy rates.

Table 403.3.1.1

REQUIRED OUTDOOR VENTILATION AIR

(The following categories in Table 403.3.1.1 have been modified. The remainder remain as printed in the 2018 International Mechanical Code)

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Offices				
Conference rooms	50	5	0.06	—
Kitchenettes ^k	25	5	0.06	0.30
Office spaces	5	5	0.06	—
Reception areas	30	5	0.06	—
Telephone/data entry	60	5	0.06	—
Main entry lobbies	10	5	0.06	—
Private dwellings, single and multiple				
Garages, common for multiple units ^b	—	—	—	0.75 See Table 403.4.7
Living areas ^c	—	See Table 403.4.2	—	—
Toilet rooms and bathrooms ^g	—	—	—	See Table 403.4.7
Public spaces				
Corridors serving other than Group R occupancies	—	—	0.06	—
Corridors serving Group R dwelling or sleeping units with whole house exhaust system	—	—	0.12	—
Corridors serving Group R dwelling or sleeping units with other than whole house exhaust system	—	—	0.06	—
Courtrooms	70	5	0.06	—
Elevator car	—	—	—	1
Elevator lobbies in parking garage	—	—	1.0	—
Legislative chambers	50	5	0.06	—
Libraries	10	5	0.12	—
Museums (children's)	40	7.5	0.12	—
Museums/galleries	40	7.5	0.06	—
Places of religious worship	120	5	0.06	—
Shower room (per showerhead) ^g	—	—	—	50/20 ^f
Smoking lounges ^b	70	60	—	—

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Toilet rooms—Public ^g	—	—	—	50/70 ^e
Sports and amusement				
Disco/dance floors	100	20	0.06	—
Bowling alleys (seating areas)	40	10	0.12	—
Game arcades	20	7.5	0.18	—
Ice arenas, without combustion engines ^j	—	—	0.30	0.5
Gym, stadium, arena (play area) ^j	—	—	0.30	—
Spectator areas	150	7.5	0.06	—
Swimming pools (pool and deck area)	—	—	0.48	—
Health club/aerobics room	40	20	0.06	—
Health club/weight room	10	20	0.06	—
Storage				
Janitor closets, trash rooms, recycling rooms	—	—	—	1.0
Repair garages, enclosed parking garage ^{b, d}	—	—	—	0.75
Storage rooms, chemical	—	—	—	1.5
Warehouses	—	—	0.06	—
Workrooms				
Bank vaults/safe deposit	5	5	0.06	—
Darkrooms	—	—	—	1.0
Copy, printing rooms	4	5	0.06	0.5
Freezer and refrigerated spaces (<50°F)	0	10	0	0
Meat processing ^c	10	15	—	—
Pharmacy (prep. area)	10	5	0.18	—
Photo studios	10	5	0.12	—
Computer (without printing)	4	5	0.06	—

For SI: 1 cubic foot per minute = 0.0004719 m³/s, 1 ton = 908 kg, 1 cubic foot per minutes per square foot = 0.00508 m³/(s•m²), °C = [(°F) -32]/1.8, 1 square foot = 0.0929 m².

- a. Based upon *net occupiable floor area*.
- b. Mechanical exhaust required and the recirculation of air from such spaces is prohibited. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Item 3).
- c. Spaces unheated or maintained below 50°F are not covered by these requirements unless the occupancy is continuous.
- d. Ventilation systems in enclosed parking garages shall comply with Section 404.
- e. Rates are per water closet or urinal. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- f. Rates are per room unless otherwise indicated. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- g. Mechanical exhaust is required and recirculation from such spaces is prohibited except that recirculation shall be permitted where the resulting supply airstream consists of not more than 10 percent air recirculated from these spaces. Return air from such spaces only be permitted to be recirculated when returned to an energy recovery ventilation system complying with Section 514. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Items 2 and 4).
- h. For nail salons, each manicure and pedicure station shall be provided with a *source capture system* capable of exhausting not less than 50 cfm per station. Exhaust inlets shall be located in accordance with Section 502.20. Where one or more required source capture systems operate continuously during occupancy, the exhaust rate from such systems shall be permitted to be applied to the exhaust flow rate required by Table 403.3.1.1 for the nail salon.
- i. Reserved.
- j. When combustion equipment is intended to be used on the playing surface, additional dilution ventilation and/or source control shall be provided.
- k. Kitchenettes require exhaust when they contain a domestic cooking appliance range or oven that is installed in accordance with Table 507.2.1. Kitchenettes that only contain a microwave cooking appliance are not required to have exhaust. A kitchenette may not contain commercial cooking appliances that require Type I or Type II exhaust as these occupancies are required to be exhausted to the kitchen category in Table 403.3.1.1.

403.3.1.1.2.3 Multiple zone recirculating systems. For ventilation systems wherein one or more air handlers supply a mixture of outdoor air and recirculated air to more than one ventilation zone, the outdoor air intake flow (V_{ot}) shall be determined in accordance with Sections 403.3.1.1.2.3.1 through 403.3.1.1.2.3.4.

403.3.1.1.2.3.1 Uncorrected outdoor air intake. The uncorrected outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-5.

$$V_{ou} = D \sum_{all\ zones} (R_p \times P_z) + \sum_{all\ zones} (R_a \times A_z) \quad \text{(Equation 4-5)}$$

403.3.1.1.2.3.1.1 Occupant diversity. The occupant diversity ratio (D) shall be determined in accordance with Equation 4-6 to account for variations in population within the ventilation zones served by the system.

$$D = P_s / \sum_{all\ zones} P_z \quad \text{(Equation 4-6)}$$

where:

P_s = System population: The total population in the area served by the system.

EXCEPTION: Alternative methods to account for occupant diversity shall be permitted, provided the resulting V_{ou} value is no less than that determined using Equation 4-5.

403.3.1.1.2.3.1.2 Design system population. Design system population (P_s) shall equal the largest (peak) number of people expected to occupy all ventilation zones served by the ventilation system during use.

Note: Design system population is always equal to or less than the sum of design zone population for all zones in the area served by the system because all zones may or may not be simultaneously occupied at design population.

403.3.1.1.2.3.2 System ventilation efficiency. The system ventilation efficiency (E_v) shall be determined in accordance with Section 403.3.1.1.2.3.3 for the Simplified Procedure or Appendix A of ASHRAE 62.1 for the Alternative Procedure.

Note: These procedures also establish zone minimum primary airflow rates for VAV systems.

403.3.1.1.2.3.3 Simplified procedure.

403.3.1.1.2.3.3.1 System ventilation efficiency. System ventilation efficiency (E_v) shall be determined in accordance with Equation 4-6a or 4-6b.

$$E_v = 0.88 \times D + 0.22 \text{ for } D < 0.60 \quad \text{(Equation 4-6a)}$$

$$E_v = 0.75 \text{ for } D \geq 0.60 \quad \text{(Equation 4-6b)}$$

403.3.1.1.2.3.3.2 Zone minimum primary airflow. For each zone, the minimum primary airflow (V_{pz-min}) shall be determined in accordance with Equation 4-7.

$$V_{pz-min} = V_{oz} \times 1.5 \quad \text{(Equation 4-7)}$$

403.3.1.1.2.3.4 Outdoor air intake. The design outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-8.

$$V_{ot} = V_{ou} / E_v \quad \text{(Equation 4-8)}$$

403.3.2 Group R-2, R-3 and R-4 occupancies. This section is not adopted. See Section 403.4.

403.3.2.1 Outdoor air for dwelling units. This section is not adopted.

403.3.2.2 Outdoor air for other spaces. This section is not adopted.

403.3.2.3 Local exhaust. This section is not adopted.

403.4 Group R whole house mechanical ventilation system. Each dwelling unit or sleeping unit shall be equipped with a whole house mechanical ventilation system that complies with Sections 403.4.1 through 403.4.6. Each dwelling unit or sleeping unit shall be equipped with local exhaust complying with Section 403.4.7. All occupied spaces, including public corridors, other than the Group R dwelling units and/or sleeping units, that support these Group R occupancies shall meet the ventilation requirement of natural ventilation requirements of Section 402 or the mechanical ventilation requirements of Sections 403.1 through 403.3.

403.4.1 System design. The whole house ventilation system shall consist of one or more supply fans, one or more exhaust fans, or an ERV/HRV with integral fans; and the associated ducts and controls. Local exhaust fans shall be permitted to serve as part of the whole house ventilation system when provided with the proper controls in accordance with Section 403.4.5. The systems shall be designed and installed to supply and exhaust the minimum outdoor airflow rates per Section 403.4.2 as corrected by the balanced and/or distributed whole house ventilation system coefficients in accordance with Section 403.4.3 where applicable.

Table 403.4.2
WHOLE HOUSE MECHANICAL VENTILATION AIRFLOW RATE
(CONTINUOUSLY OPERATING SYSTEMS)

Floor Area (ft ²)	Bedrooms ¹				
	1	2	3	4	>5
<500	30	30	35	45	50
500 - 1000	30	35	40	50	55
1001 - 1500	30	40	45	55	60
1501 - 2000	35	45	50	60	65
2001 - 2500	40	50	55	65	70
2501 - 3000	45	55	60	70	75
3001 - 3500	50	60	65	75	80
3501 - 4000	55	65	70	80	85
4001 - 4500	60	70	75	85	90
4501 - 5000	65	75	80	90	95

¹ Minimum airflow (Q_r) is set at not less than 30 cfm for each dwelling units.

403.4.2 Whole house mechanical ventilation rates. The sleeping unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates requirements of Section 403.3.1.1.1.2 using Equation 4-2. The dwelling unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with Equation 4-10 or Table 403.4.2.

$$Q_r = 0.01 * A_{\text{floor}} + 7.5 * (N_{\text{br}} + 1) \quad \text{(Equation 4-10)}$$

where:

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) but not less than 30 cfm for each dwelling unit.

A_{floor} = Conditioned floor area, square feet (ft²)

N_{br} = Number of bedrooms, not less than one.

Table 403.4.3
SYSTEM COEFFICIENT (C_{system})

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

403.4.3 Ventilation quality adjustment. The minimum whole house ventilation rate from Section 403.4.2 shall be adjusted by the system coefficient in Table 403.4.3 based on the system type not meeting the definition of a balanced whole house ventilation system and/or not meeting the definition of a distributed whole house ventilation system.

$$Q_v = Q_r * C_{system} \text{ (Equation 4-11)}$$

where:

Q_v = Quality-adjusted ventilation airflow rate in cubic feet per minute (cfm)

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) from Equation 4-10 or Table 403.4.1

C_{system} = System coefficient from Table 403.4.3

403.4.4 Whole house ventilation residential occupancies. Residential dwelling and sleeping unit whole house ventilation systems shall meet the requirements of Sections 403.4.4.1 or 403.4.4.2 depending on the occupancy of the residential unit.

403.4.4.1 Whole house ventilation in Group R-2 occupancies. Residential dwelling and sleeping units in Group R-2 occupancies system shall include supply and exhaust fans and be a balanced whole house ventilation system in accordance with Section 403.4.6.3. The system shall include a heat or energy recovery ventilator with a sensible heat recovery effectiveness as prescribed in Section C403.3.6 of the *Washington State Energy Code*. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

403.4.4.2 Whole house ventilation for other than Group R-2 occupancies. Residential dwelling and sleeping units in other than Group R-2 occupancies, including I-1 condition 2 occupancies, shall have a whole house mechanical ventilation system with supply and exhaust fans in accordance with Section 403.4.6.1, 403.4.6.2, 403.4.6.3, or 403.4.6.4. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4.2 unless configured with intermittent off controls in accordance with Section 403.4.6.5. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

403.4.5 Whole house ventilation controls.

1. The whole house ventilation system shall be controlled with manual switches, timers or other means that provide for automatic operation of the ventilation system that are readily accessible by the occupant;

2. Whole house mechanical ventilation system shall be provided with controls that enable manual override off of the system by the oc-

cupant during periods of poor outdoor air quality. Controls shall include permanent text or a symbol indicating their function. Recommended control permanent labeling to include text similar to the following: "Leave on unless outdoor air quality is very poor." Manual controls shall be provided with ready access for the occupant.

EXCEPTION: Central whole house mechanical systems with supply air and/or exhaust that serve more than one dwelling or sleep units are not required to have manual override off controls accessible to the occupant.

3. Whole house ventilation systems shall be configured to operating continuously except where intermittent off controls are provided in accordance with Section 403.4.6.5 and allowed by Section 403.4.4.2.

403.4.6 Whole house ventilation system component requirements. Whole house ventilation supply and exhaust fans specified in this section shall have a minimum efficacy as prescribed in the *Washington State Energy Code*. The fans shall be rated for sound at a maximum of 1.0 sone at design airflow and static pressure conditions. Design and installation of the system or equipment shall be carried out in accordance with manufacturer's installation instructions.

EXCEPTIONS: 1. Central supply or exhaust fans serving multiple residential units do not need to comply with the maximum fan sone requirements.
2. Interior joining spaces provided with a 30 cfm transfer fan or a 25 square foot permanent opening do not require supply ventilation air directly to the space. Transfer fans shall meet the sone rating above and have whole house ventilation controls in accordance with Section 403.4.5.

403.4.6.1 Exhaust fans. Exhaust fans required shall be ducted directly to the outside in accordance with Section 501.3. Exhaust air outlets shall be designed to limit the pressure difference to the outside to limiting the outlet free area maximum velocity to 500 feet per minute and equipped with backdraft dampers or motorized dampers in accordance with *Washington State Energy Code*. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Exhaust fans required in this section may be used to provide local ventilation. Exhaust fans that are designed for intermittent exhaust airflow rates higher than the continuous exhaust airflow rates in Table 403.4.2 shall be provided with occupancy sensors or humidity sensors to automatically override the fan to the high speed airflow rate. The exhaust fans shall be tested and the testing results shall be submitted and posted in accordance with Section 403.4.6.7.

EXCEPTION: Central exhaust fans serving multiple residential units do not need to comply with the HVI testing requirements.

403.4.6.2 Supply fans. Supply fans used in meeting the requirements of this section shall supply outdoor air from intake openings in accordance with Sections 401.4 and 401.5. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 feet per minute and when designed for intermittent off operation shall be equipped with motorized dampers in accordance with the *Washington State Energy Code*. Supply fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Where outdoor air is provided to each habitable dwelling unit or sleeping unit by supply fan systems the outdoor air shall be filtered. The filter shall be provided with access for regular maintenance and replacement. The filter shall have a Minimum Efficiency Rating Value (MERV) of at least 8.

EXCEPTION: Central supply fans serving multiple residential units do not need to comply with the HVI testing requirements.

403.4.6.3 Balanced whole house ventilation system. A balanced whole house ventilation system shall include both supply and exhaust fans. The supply and exhaust fans shall have airflow that is within 10 percent of each other. The tested and balanced total mechanical exhaust

airflow rate is within 10 percent or 5 cfm, whichever is greater, of the total mechanical supply airflow rate. The flow rate test results shall be submitted and posted in accordance with Section 403.4.6.7. The exhaust fan shall meet the requirements of Section 403.4.6.1. The supply fan shall meet the requirements of Section 403.4.6.2. For R-2 dwelling and sleeping units, the system is required to have balanced whole house ventilation but is not required to have distributed whole house ventilation where the not distributed system coefficient from Table 403.4.3 is utilized to correct the whole house mechanical ventilation rate. The system shall be design and balanced to meet the pressure equalization requirements of Section 501.4. Intermittent dryer exhaust, intermittent range hood exhaust, and intermittent toilet room exhaust airflow rates above the residential dwelling or sleeping unit minimum ventilation rate are exempt from the balanced airflow calculation.

403.4.6.4 Furnace integrated supply. Systems using space condition heating and/or cooling air handler fans for outdoor air supply air distribution are not permitted.

EXCEPTION: Air handler fans shall be permitted that have multi-speed or variable speed supply airflow control capability with a low speed operation not greater than 25 percent of the rated supply air flow capacity during ventilation only operation. Outdoor air intake openings must meet the provisions of Sections 401.4 and 401.5 and must include a motorized damper that is activated by the whole house ventilation system controller. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 ft per min. The motorized damper must be controlled to maintain the outdoor airflow intake airflow within 10 percent of the whole house mechanical exhaust airflow rate. The supply air handler shall provide supply air to each habitable space in the residential unit. The whole house ventilation system shall include exhaust fans in accordance with Section 403.4.6.1 to meet the pressure equalization requirements of Section 501.4. The flow rate for the outdoor air intake must be tested and verified at the minimum ventilation fan speed and the maximum heating or cooling fan speed. The results of the test shall be submitted and posted in accordance with Section 403.4.6.7.

403.4.6.5 Intermittent off operation. Whole house mechanical ventilation systems shall be provided with advanced controls that are configured to operate the system with intermittent off operation and shall operate for a least two hours in each four-hour segment. The whole house ventilation airflow rate determined in accordance with Section 403.4.2 as corrected by Section 403.4.3 shall be multiplied by the factor determined in accordance with Table 403.4.6.5.

Table 403.4.6.5
INTERMITTENT WHOLE HOUSE MECHANICAL VENTILATION RATE
FACTORS^{a, b}

Run-time Percentage in Each 4-hour Segment	50%	66%	75%	100%
Factor ^a	2	1.5	1.3	1.0

^a For ventilation system run-time values between those given, the factors are permitted to be determined by interpolation.

^b Extrapolation beyond the table is prohibited.

403.4.6.6 Testing. Whole house mechanical ventilation systems shall be tested, balanced and verified to provide a flow rate not less than the minimum required by Sections 403.4.2 and 403.4.3. Testing shall be performed according to the ventilation equipment manufacturer's instructions, or by using a flow hood, flow grid, or other airflow measuring device at the mechanical ventilation fan's inlet terminals, outlet terminals or grilles or in the connected ventilation ducts. Where required by the building official, testing shall be conducted by an approved third party. A written report of the results of the test

shall be signed by the party conducting the test and provided to the building official and shall be posted in the residential unit in accordance with Section 403.4.6.7.

403.4.6.7 Certificate. A permanent certificate shall be completed by the mechanical contractor, test and balance contractor or other approved party and posted on a wall in the space where the furnace is located, a utility room, or an approved location inside the building. When located on an electrical panel, the certificate shall not cover or obstruct the visibility of the circuit directory label, service disconnect label, or other required labels. The certificate shall list the flow rate determined from the delivered airflow of the whole house mechanical ventilation system as installed and the type of mechanical whole house ventilation system used to comply with Section 403.4.3.

403.4.7 Local exhaust. Bathrooms, toilet rooms and kitchens shall include a local exhaust system. Such local exhaust systems shall have the capacity to exhaust the minimum airflow rate in accordance with Table 403.4.7 and Table 403.3.1.1, including notes. Fans required by this section shall be provided with controls that enable manual override or automatic occupancy sensor, humidity sensor or pollutant sensor controls. An "on/off" switch shall meet this requirement for manual controls. Manual fan controls shall be provided with ready access in the room served by the fan.

Table 403.4.7
MINIMUM EXHAUST RATES

Area to be exhausted	Exhaust Rate	
	Intermittent	Continuous
Kitchens	100 cfm	30 cfm
Bathrooms - Toilet rooms	50 cfm	20 cfm

403.4.7.1 Whole house exhaust controls. If the local exhaust fan is included in a whole house ventilation system in accordance with Section 403.4.6, the exhaust fan shall be controlled to operate as specified in Section 403.4.5.

403.4.7.2 Local exhaust fans. Exhaust fans shall meet the following criteria.

1. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920.

EXCEPTION: Where a range hood or down draft exhaust fan is used for local exhaust for a kitchen, the device is not required to be rated per these standards.

2. Fan airflow rating and duct system shall be designed and installed to deliver at least the exhaust airflow required by Table 403.4.7. The airflows required refer to the delivered airflow of the system as installed and tested using a flow hood, flow grid, or other airflow measurement device. Local exhaust systems shall be tested, balanced and verified to provide a flow rate not less than the minimum required by this section.

3. Design and installation of the system or equipment shall be carried out in accordance with manufacturers' installation instructions.

4. Fan airflow rating and duct system shall be designed and installed to deliver at least the exhaust airflow required by Table 403.4.3.

- EXCEPTIONS:
1. An exhaust airflow rating at a pressure of 0.25 in. w.g. may be used, provided the duct sizing meets the prescriptive requirements of Table 403.4.7.2.
 2. Where a range hood or down draft exhaust fan is used to satisfy the local ventilation requirements for kitchens, the range hood or down draft exhaust shall not be less than 100 cfm at 0.10 in. w.g.

Table 403.4.7.2
PRESCRIPTIVE EXHAUST DUCT SIZING

Fan Tested cfm at 0.25 inches w.g.	Minimum Flex Diameter	Maximum Length in Feet	Minimum Smooth Diameter	Maximum Length in Feet	Maximum Elbows ^a
50	4 inches	25	4 inches	70	3
50	5 inches	90	5 inches	100	3
50	6 inches	No Limit	6 inches	No Limit	3
80	4 inches ^b	NA	4 inches	20	3
80	5 inches	15	5 inches	100	3
80	6 inches	90	6 inches	No Limit	3
100	5 inches ^b	NA	5 inches	50	3
100	6 inches	45	6 inches	No Limit	3
125	6 inches	15	6 inches	No Limit	3
125	7 inches	70	7 inches	No Limit	3

- a. For each additional elbow, subtract 10 feet from length.
- b. Flex ducts of this diameter are not permitted with fans of this size.

[Statutory Authority: RCW 19.27.031, 19.27.074, and chapter 19.27 RCW. WSR 22-09-009, § 51-52-0403, filed 4/8/22, effective 5/9/22. Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-05-020, § 51-52-0403, filed 2/8/21, effective 3/11/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-03-041, § 51-52-0403, filed 1/8/20, effective 7/1/20; WSR 17-10-075, § 51-52-0403, filed 5/3/17, effective 6/3/17; WSR 16-01-148, § 51-52-0403, filed 12/21/15, effective 7/1/16. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-053, § 51-52-0403, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031, 19.27.035, 19.27.074, and chapters 19.27 and 34.05 RCW. WSR 12-07-020, § 51-52-0403, filed 3/12/12, effective 4/12/12. Statutory Authority: RCW 19.27.190, 19.27.074, 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 10-03-099, § 51-52-0403, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.190, 19.27.020, and chapters 19.27 and 34.05 RCW. WSR 07-01-092, § 51-52-0403, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 05-01-015, § 51-52-0403, filed 12/2/04, effective 7/1/05.]

Reviser's note: The brackets and enclosed material in the text of the above section occurred in the copy filed by the agency.

(Effective March 15, 2024)

WAC 51-52-0403 Section 403—Mechanical ventilation.

403.1 Ventilation system. Mechanical ventilation shall be provided by a method of supply air and return or *exhaust air*. The amount of supply air shall be approximately equal to the amount of return and *exhaust air*. The system shall not be prohibited from producing negative or positive pressure. The system to convey ventilation air shall be designed and installed in accordance with Chapter 6.

403.2 Outdoor air required. The minimum *outdoor airflow rate* shall be determined in accordance with Section 403.3.

- EXCEPTIONS:
1. Where the registered design professional demonstrates that an engineered ventilation system design will prevent the maximum concentration of contaminants from exceeding that obtainable by the rate of *outdoor air* ventilation determined in accordance with Section 403.3, the minimum required rate of *outdoor air* shall be reduced in accordance with such engineered system design.
 2. Alternate systems designed in accordance with ASHRAE Standard 62.1 Section 6.2, Ventilation Rate Procedure, shall be permitted.

403.2.1 Recirculation of air. The air required by Section 403.3 shall not be recirculated. Air in excess of that required by Section 403.3 shall not be prohibited from being recirculated as a component of supply air to building spaces, except that:

1. Ventilation air shall not be recirculated from one dwelling to another or to dissimilar occupancies.

2. Supply air to a swimming pool and associated deck areas shall not be recirculated unless such air is dehumidified to maintain the relative humidity of the area at 60 percent or less. Air from this area shall not be recirculated to other spaces where 10 percent or more of the resulting supply airstream consists of air recirculated from these spaces. The design and installation of dehumidification systems shall comply with ANSI/ACCA 10 Manual SPS.

3. Where mechanical exhaust is required by Note b in Table 403.3.1.1, recirculation of air from such spaces shall be prohibited. All air supplied to such spaces shall be exhausted, including any air in excess of that required by Table 403.3.1.1.

4. Where mechanical exhaust is required by Note g in Table 403.3.1.1, mechanical exhaust is required and recirculation from such spaces is prohibited where more than 10 percent of the resulting supply airstream consists of air recirculated from these spaces. Recirculation of air that is contained completely within such spaces shall not be prohibited.

403.3 Outdoor air and local exhaust airflow rates. Group R occupancies shall be provided with outdoor air and local exhaust in accordance with Section 403.4. All other buildings intended to be occupied shall be provided with outdoor air and local exhaust in accordance with Section 403.3.1.

403.3.1.1 Outdoor airflow rate. Ventilation systems shall be designed to have the capacity to supply the minimum outdoor airflow rate determined in accordance with this section. In each occupiable space, the ventilation system shall be designed to deliver the required rate of outdoor airflow to the breathing zone. Outdoor air shall be supplied directly to each occupiable space from an air handling unit through a fully ducted path or ducted to within 12 inches of the return air opening of a fan-powered terminal unit used to transfer the outdoor air to the occupiable space. The occupant load utilized for design of the ventilation system shall not be less than the number determined from the estimated maximum occupant load rate indicated in Table 403.3.1.1. Ventilation rates for occupancies not represented in Table 403.3.1.1 shall be those for a listed occupancy classification that is most similar in terms of occupant density, activities and building construction; or shall be determined by an approved engineering analysis. The ventilation system, including transfer fan-powered terminal units shall be designed to supply the required rate of ventilation air continuously during the period the building is occupied, except as otherwise stated in other provisions of the code.

With the exception of smoking lounges, the ventilation rates in Table 403.3.1.1 are based on the absence of smoking in occupiable spaces. Where smoking is anticipated in a space other than a smoking lounge, the ventilation system serving the space shall be designed to provide ventilation over and above that required by Table 403.3.1.1 in accordance with accepted engineering practice.

EXCEPTION: Where occupancy density is known and documented in the plans, the outside air rate may be based on the design occupant density. Under no circumstance shall the occupancies used result in outside air less than one-half that resulting from application of Table 403.3.1.1 estimated maximum occupancy rates.

Table 403.3.1.1
REQUIRED OUTDOOR VENTILATION AIR

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone <i>R_p</i> cfm/Person	Area Outdoor Airflow Rate in Breathing Zone <i>R_a</i> cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Correctional facilities				
Booking/waiting	50	7.5	0.06	—
Cells				
Without plumbing fixtures	25	5	0.12	—
With plumbing fixtures ^g	25	5	0.12	1.0
Day room	30	5	0.06	—
Dining halls	—	—	—	—
(see "Food and beverage service")	—	—	—	—
Guard stations	15	5	0.06	—
Dry cleaners, laundries				
Coin-operated dry cleaner	20	15	—	—
Coin-operated laundries	20	7.5	0.12	—
Commercial dry cleaner	30	30	—	—
Commercial laundry	10	5	0.12	—
Storage, pick up	30	7.5	0.12	—
Education				
Art classroom ^g	20	10	0.18	0.7
Auditoriums	150	5	0.06	—
Classrooms (ages 5 through 8)	25	10	0.12	—
Classrooms (age 9 plus)	35	10	0.12	—
Computer lab	25	10	0.12	—
Corridors (see "Public spaces")	—	—	—	—
Day care (through age 4)	25	10	0.18	—
Lecture classroom	65	7.5	0.06	—
Lecture hall (fixed seats)	150	7.5	0.06	—
Locker/dressing rooms ^g	—	—	—	0.25
Media center	25	10	0.12	—
Multiuse assembly	100	7.5	0.06	—
Music/theater/dance	35	10	0.06	—
Science laboratories ^g	25	10	0.18	1.0
Smoking lounges ^b	70	60	—	—
Sports locker rooms ^g	—	—	—	0.5
Wood/metal shops ^g	20	10	0.18	0.5
Food and beverage service				
Bars, cocktail lounges	100	7.5	0.18	—
Cafeteria, fast food	100	7.5	0.18	—
Dining rooms	70	7.5	0.18	—
Kitchens (cooking) ^b	20	7.5	0.12	0.7
Hotels, motels, resorts, and dormitories				
Bathrooms/toilets—private ^g	—	—	—	25/50 ^f
Bedroom/living room	10	5	0.06	—
Conference/meeting	50	5	0.06	—
Dormitory sleeping area	20	5	0.06	—
Gambling casinos	120	7.5	0.18	—
Lobbies/prefunction	30	7.5	0.06	—
Multipurpose assembly	120	50	0.06	—

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Offices				
Conference rooms	50	5	0.06	—
Kitchenettes ^k	25	5	0.06	0.30
Office spaces	5	5	0.06	—
Reception areas	30	5	0.06	—
Telephone/data entry	60	5	0.06	—
Main entry lobbies	10	5	0.06	—
Private dwellings, single and multiple				
Garages, common for multiple units ^b	—	—	—	0.75
Kitchens ^b	—	—	—	See Table 403.4.7
Living areas ^c	—	See Table 403.4.2	—	—
Toilet rooms and bathrooms ^g	—	—	—	See Table 403.4.7
Public spaces				
Corridors serving other than Group R occupancies	—	—	0.06	—
Corridors serving Group R dwelling or sleeping units with whole house exhaust system	—	—	0.12	—
Corridors serving Group R dwelling or sleeping units with other than whole house exhaust system	—	—	0.06	—
Courtrooms	70	5	0.06	—
Elevator car	—	—	—	1
Elevator lobbies in parking garage	—	—	1.0	—
Legislative chambers	50	5	0.06	—
Libraries	10	5	0.12	—
Museums (children's)	40	7.5	0.12	—
Museums/galleries	40	7.5	0.06	—
Places of religious worship	120	5	0.06	—
Shower room (per showerhead) ^g	—	—	—	50/20 ^f
Smoking lounges ^b	70	60	—	—
Toilet rooms—Public ^g	—	—	—	50/70 ^e
Retail stores, sales floors, and showroom floors				
Dressing rooms	—	—	—	0.25
Mall common areas	40	7.5	0.06	—
Sales	15	7.5	0.12	—
Shipping and receiving	2	10	0.12	—
Smoking lounges ^b	70	60	—	—
Storage rooms	—	—	0.12	—
Warehouses (see "Storage")	—	10	0.06	—
Specialty shops				
Automotive motor fuel-dispensing stations ^b	—	—	—	1.5
Barber	25	7.5	0.06	0.5
Beauty salons ^b	25	20	0.12	0.6
Embalming rooms ^b	—	—	—	2.0
Nail salons ^{b,h}	25	20	0.12	0.6
Pet shops (animal areas) ^b	10	7.5	0.18	0.9
Supermarkets	8	7.5	0.06	—
Sports and amusement				
Disco/dance floors	100	20	0.06	—
Bowling alleys (seating areas)	40	10	0.12	—

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Game arcades	20	7.5	0.18	—
Ice arenas, without combustion engines ^j	—	—	0.30	0.5
Gym, stadium, arena (play area) ^j	—	—	0.30	—
Spectator areas	150	7.5	0.06	—
Swimming pools (pool and deck area)	—	—	0.48	—
Health club/aerobics room	40	20	0.06	—
Health club/weight room	10	20	0.06	—
Storage				
Janitor closets, trash rooms, recycling rooms	—	—	—	1.0
Repair garages, enclosed parking garage ^{b, d}	—	—	—	0.75
Storage rooms, chemical	—	—	—	1.5
Warehouses	—	—	0.06	—
Theaters				
Auditoriums (see "Education")	—	—	—	—
Lobbies	150	5	0.06	—
Stages, studios	70	10	0.06	—
Ticket booths	60	5	0.06	—
Transportation				
Platforms	100	7.5	0.06	—
Transportation waiting	100	7.5	0.06	—
Workrooms				
Bank vaults/safe deposit	5	5	0.06	—
Darkrooms	—	—	—	1.0
Copy, printing rooms	4	5	0.06	0.5
Freezer and refrigerated spaces (<50°F)	0	10	0	0
Meat processing ^c	10	15	—	—
Pharmacy (prep. area)	10	5	0.18	—
Photo studios	10	5	0.12	—
Computer (without printing)	4	5	0.06	—

For SI: 1 cubic foot per minute = 0.0004719 m³/s, 1 ton = 908 kg, 1 cubic foot per minutes per square foot = 0.00508 m³/(s•m²), °C = [(°F) -32]/1.8, 1 square foot = 0.0929 m².

- a. Based upon *net occupiable floor area*.
- b. Mechanical exhaust required and the recirculation of air from such spaces is prohibited. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Item 3).
- c. Spaces unheated or maintained below 50°F are not covered by these requirements unless the occupancy is continuous.
- d. Ventilation systems in enclosed parking garages shall comply with Section 404.
- e. Rates are per water closet or urinal. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- f. Rates are per room unless otherwise indicated. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- g. Mechanical exhaust is required and recirculation from such spaces is prohibited. For occupancies other than science laboratories, where there is a wheel-type energy recovery ventilation (ERV) unit in the exhaust system design, the volume of air leaked from the exhaust airstream into the outdoor airstream within the ERV shall be less than 10 percent of the outdoor air volume. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Items 2 and 4).
- h. For nail salons, each manicure and pedicure station shall be provided with a *source capture system* capable of exhausting not less than 50 cfm per station. Exhaust inlets shall be located in accordance with Section 502.20. Where one or more required source capture systems operate continuously during occupancy, the exhaust rate from such systems shall be permitted to be applied to the exhaust flow rate required by Table 403.3.1.1 for the nail salon.
- i. Reserved.
- j. When combustion equipment is intended to be used on the playing surface, additional dilution ventilation and/or source control shall be provided.
- k. Kitchenettes require exhaust when they contain a domestic cooking appliance range or oven that is installed in accordance with Table 507.1.2. Kitchenettes that only contain a microwave cooking appliance are not required to have exhaust. A kitchenette may not contain commercial cooking appliances that require Type I or Type II exhaust as these occupancies are required to be exhausted to the kitchen category in Table 403.3.1.1.

403.3.1.1.2.3 Multiple zone recirculating systems. For ventilation systems wherein one or more air handlers supply a mixture of outdoor air and recirculated air to more than one ventilation zone, the out-

door air intake flow (V_{ot}) shall be determined in accordance with Sections 403.3.1.1.2.3.1 through 403.3.1.1.2.3.4.

403.3.1.1.2.3.1 Uncorrected outdoor air intake. The uncorrected outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-5.

$$V_{ou} = D \sum_{all\ zones} (R_p \times P_z) + \sum_{all\ zones} (R_a \times A_z) \quad \text{(Equation 4-5)}$$

403.3.1.1.2.3.1.1 Occupant diversity. The occupant diversity ratio (D) shall be determined in accordance with Equation 4-6 to account for variations in population within the ventilation zones served by the system.

$$D = P_s / \sum_{all\ zones} P_z \quad \text{(Equation 4-6)}$$

where:

P_s = System population: The total population in the area served by the system.

EXCEPTION: Alternative methods to account for occupant diversity shall be permitted, provided the resulting V_{ou} value is no less than that determined using Equation 4-5.

403.3.1.1.2.3.1.2 Design system population. Design system population (P_s) shall equal the largest (peak) number of people expected to occupy all ventilation zones served by the ventilation system during use.

Note: Design system population is always equal to or less than the sum of design zone population for all zones in the area served by the system because all zones may or may not be simultaneously occupied at design population.

403.3.1.1.2.3.2 System ventilation efficiency. The system ventilation efficiency (E_v) shall be determined in accordance with Section 403.3.1.1.2.3.3 for the Simplified Procedure or Appendix A of ASHRAE 62.1 for the Alternative Procedure.

Note: These procedures also establish zone minimum primary airflow rates for VAV systems.

403.3.1.1.2.3.3 Simplified procedure.

403.3.1.1.2.3.3.1 System ventilation efficiency. System ventilation efficiency (E_v) shall be determined in accordance with Equation 4-6a or 4-6b.

$$E_v = 0.88 \times D + 0.22 \text{ for } D < 0.60 \quad \text{(Equation 4-6a)}$$

$$E_v = 0.75 \text{ for } D \geq 0.60 \quad \text{(Equation 4-6b)}$$

403.3.1.1.2.3.3.2 Zone minimum primary airflow. For each zone, the minimum primary airflow (V_{pz-min}) shall be determined in accordance with Equation 4-7.

$$V_{pz-min} = V_{oz} \times 1.5 \quad \text{(Equation 4-7)}$$

403.3.1.1.2.3.4 Outdoor air intake. The design outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-8.

$$V_{ot} = V_{ou} / E_v \quad \text{(Equation 4-8)}$$

403.3.2 Group R-2, R-3 and R-4 occupancies. This section is not adopted. See Section 403.4.

403.3.2.1 Outdoor air for dwelling units. This section is not adopted.

403.3.2.2 Outdoor air for other spaces. This section is not adopted.

403.3.2.3 Local exhaust. This section is not adopted.

403.4 Group R whole house mechanical ventilation system. Each dwelling unit or sleeping unit shall be equipped with a whole house mechanical ventilation system that complies with Sections 403.4.1 through 403.4.6. Each dwelling unit or sleeping unit shall be equipped with local exhaust complying with Section 403.4.7. All occupied spaces, including public corridors, other than the Group R dwelling units and/or sleeping units, that support these Group R occupancies shall meet the ventilation requirement of natural ventilation requirements of Section 402 or the mechanical ventilation requirements of Sections 403.1 through 403.3.

EXCEPTION: Alternate balanced whole house ventilation systems and local exhaust systems subject to the Washington State Energy Code, Residential Provisions serving Group R dwelling units designed and commissioned in accordance with ASHRAE Standard 62.2 are permitted.

403.4.1 System design. The whole house ventilation system shall consist of one or more supply fans, one or more exhaust fans, or an ERV/HRV with integral fans; and the associated ducts and controls. Local exhaust fans shall be permitted to serve as part of the whole house ventilation system when provided with the proper controls in accordance with Section 403.4.5. The systems shall be designed and installed to supply and exhaust the minimum outdoor airflow rates in accordance with Section 403.4.2 as corrected by the balanced and/or distributed whole house ventilation system coefficients in accordance with Section 403.4.3 where applicable.

Table 403.4.2
WHOLE HOUSE MECHANICAL VENTILATION AIRFLOW RATE
(CONTINUOUSLY OPERATING SYSTEMS)

Floor Area (ft ²)	Bedrooms ¹				
	1	2	3	4	>5
<500	30	30	35	45	50
500 - 1000	30	35	40	50	55
1001 - 1500	30	40	45	55	60
1501 - 2000	35	45	50	60	65
2001 - 2500	40	50	55	65	70
2501 - 3000	45	55	60	70	75
3001 - 3500	50	60	65	75	80
3501 - 4000	55	65	70	80	85
4001 - 4500	60	70	75	85	90
4501 - 5000	65	75	80	90	95

¹ Minimum airflow (Q_r) is set at not less than 30 cfm for each dwelling units.

403.4.2 Whole house mechanical ventilation rates. The sleeping unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates requirements of Section 403.3.1.1.1.2 using Equation 4-2. The dwelling unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with Equation 4-10 or Table 403.4.2.

$$Q_r = 0.01 * A_{\text{floor}} + 7.5 * (N_{\text{br}} + 1) \quad \text{(Equation 4-10)}$$

where:

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) but not less than 30 cfm for each dwelling unit.

A_{floor} = Conditioned floor area, square feet (ft²)

N_{br} = Number of bedrooms, not less than one.

Table 403.4.3
SYSTEM COEFFICIENT (C_{system})

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

403.4.3 Ventilation quality adjustment. The minimum whole house ventilation rate from Section 403.4.2 shall be adjusted by the system coefficient in Table 403.4.3 based on the system type not meeting the definition of a *balanced whole house ventilation system* and/or not meeting the definition of a *distributed whole house ventilation system*.

$$Q_v = Q_r * C_{\text{system}} \quad \text{(Equation 4-11)}$$

where:

Q_v = Quality-adjusted ventilation airflow rate in cubic feet per minute (cfm)

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) from Equation 4-10 or Table 403.4.1

C_{system} = System coefficient from Table 403.4.3

403.4.4 Whole house ventilation residential occupancies. Residential dwelling and sleeping unit whole house ventilation systems shall meet the requirements of Sections 403.4.4.1 or 403.4.4.2 depending on the occupancy of the residential unit.

403.4.4.1 Whole house ventilation in Group R-2 occupancies. Residential dwelling and sleeping units in Group R-2 occupancies system shall include supply and exhaust fans and be a *balanced whole house ventilation system* in accordance with Section 403.4.6.3. The system shall include a heat or energy recovery ventilator with a sensible heat recovery effectiveness as prescribed in Section C403.3.6 or when selected as an option of R406 of the *Washington State Energy Code*. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

EXCEPTIONS:

1. *Interior adjoining spaces* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the adjoining space. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3.
2. *Interior adjacent rooms* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the *interior adjacent room*. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3. The interior adjacent room shall be provided with a transfer fan with a minimum airflow rate of 30 cfm or with relief air inlet with a minimum airflow of 20 cfm that is connected to the exhaust/relief air inlet of an ERV/HRV whole house ventilation system. Transfer fans that ventilate *interior adjacent rooms* shall meet the same rating in Section 403.3.6 and shall have whole house ventilation controls in accordance with Section 403.4.5.

403.4.4.2 Whole house ventilation for other than Group R-2 occupancies. Residential dwelling and sleeping units in other than Group R-2 occupancies, including I-1 condition 2 occupancies, shall have a whole house mechanical ventilation system with supply and exhaust fans in accordance with Section 403.4.6.1, 403.4.6.2, 403.4.6.3, or 403.4.6.4. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4.2 unless configured with intermittent off controls in accordance with

Section 403.4.6.5. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

EXCEPTIONS: 1. *Interior adjoining spaces* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the adjoining space. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3.
2. *Interior adjacent rooms* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the *interior adjacent room*. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3. The interior adjacent room shall be provided with a transfer fan with a minimum airflow rate of 30 cfm or with relief air inlet with a minimum airflow of 20 cfm that is connected to the exhaust/relief air inlet of an ERV/HRV whole house ventilation system. Transfer fans that ventilate *interior adjacent rooms* shall meet the same rating in Section 403.4.6 and shall have whole house ventilation controls in accordance with Section 403.4.5.

403.4.5 Whole house ventilation controls.

1. The whole house ventilation system shall be controlled with manual switches, timers or other means that provide for automatic operation of the ventilation system that are readily accessible by the occupant;

2. Whole house mechanical ventilation system shall be provided with controls that enable manual override off of the system by the occupant during periods of poor outdoor air quality. Controls shall include permanent text or a symbol indicating their function. Recommended control permanent labeling to include text similar to the following: "Leave on unless outdoor air quality is very poor." Manual controls shall be provided with ready access for the occupant.

EXCEPTION: Central whole house mechanical systems with supply air and/or exhaust that serve more than one dwelling or sleep units are not required to have manual override off controls accessible to the occupant.

3. Whole house ventilation systems shall be configured to operating continuously except where intermittent off controls are provided in accordance with Section 403.4.6.5 and allowed by Section 403.4.4.2.

403.4.6 Whole house ventilation system component requirements. Whole house ventilation supply and exhaust fans specified in this section shall have a minimum efficacy as prescribed in the *Washington State Energy Code*. The fans shall be rated for sound at a maximum of 1.0 sone at design airflow and static pressure conditions. Design and installation of the system or equipment shall be carried out in accordance with manufacturer's installation instructions.

EXCEPTIONS: 1. Central supply or exhaust fans serving multiple residential units do not need to comply with the maximum fan sone requirements.
2. Interior joining spaces provided with a 30 cfm transfer fan or a 25 square foot permanent opening do not require supply ventilation air directly to the space. Transfer fans shall meet the same rating above and have whole house ventilation controls in accordance with Section 403.4.5.

403.4.6.1 Exhaust fans. Exhaust fans required shall be ducted directly to the outside in accordance with Section 501.3. Exhaust air outlets shall be designed to limit the pressure difference to the outside to limiting the outlet free area maximum velocity to 500 feet per minute and equipped with backdraft dampers or motorized dampers in accordance with *Washington State Energy Code*. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Exhaust fans required in this section may be used to provide local ventilation. Exhaust fans serving spaces other than kitchens that are designed for intermittent exhaust rates in Table 403.4.7 shall be provided with occupancy sensors, humidity sensors, timer controls, or pollutant sensor controls to automatically override the fan to the high speed airflow rate. The exhaust fans shall be tested and the testing results shall be submitted and posted in accordance with Section 403.4.6.7.

EXCEPTIONS: 1. Central exhaust fans serving multiple residential units do not need to comply with the HVI testing requirements.
2. Inlet free area maximum velocity may exceed 500 feet per minute when a factory-built combined exhaust/intake termination fitting is used.

403.4.6.2 Supply fans. Supply fans used in meeting the requirements of this section shall supply outdoor air from intake openings in accordance with Sections 401.4 and 401.5. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 feet per minute and when designed for intermittent off operation shall be equipped with motorized dampers in accordance with the *Washington State Energy Code*. Supply fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Where outdoor air is provided to each habitable dwelling unit or sleeping unit by supply fan systems the outdoor air shall be filtered. The filter shall be provided with access for regular maintenance and replacement. The filter shall have a Minimum Efficiency Rating Value (MERV) of at least 8.

EXCEPTION: Central supply fans serving multiple residential units do not need to comply with the HVI testing requirements.

403.4.6.3 Balanced whole house ventilation system. A balanced whole house ventilation system shall include both supply and exhaust fans. The supply and exhaust fans shall have airflow that is within 10 percent of each other. The tested and balanced total mechanical exhaust airflow rate is within 10 percent or 5 cfm, whichever is greater, of the total mechanical supply airflow rate. The flow rate test results shall be submitted and posted in accordance with Section 403.4.6.7. The exhaust fan shall meet the requirements of Section 403.4.6.1. The supply fan shall meet the requirements of Section 403.4.6.2. For Group R-2 dwelling and sleeping units, the system is required to have balanced whole house ventilation but is not required to have distributed whole house ventilation where the not distributed system coefficient from Table 403.4.3 is utilized to correct the whole house mechanical ventilation rate. The system shall be designed and balanced to meet the pressure equalization requirements of Section 501.4. Local exhaust systems that are not a component of the whole-house mechanical ventilation system are exempt from the balanced airflow calculation.

403.4.6.4 Furnace integrated supply. Systems using space condition heating and/or cooling air handler fans for outdoor air supply air distribution are not permitted.

EXCEPTION: Air handler fans shall be permitted that have multi-speed or variable speed supply airflow control capability with a low speed operation not greater than 25 percent of the rated supply air flow capacity during ventilation only operation. Outdoor air intake openings must meet the provisions of Sections 401.4 and 401.5 and must include a motorized damper that is activated by the whole house ventilation system controller. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 ft per min. The motorized damper must be controlled to maintain the outdoor airflow intake airflow within 10 percent of the whole house mechanical exhaust airflow rate. The supply air handler shall provide supply air to each habitable space in the residential unit. The whole house ventilation system shall include exhaust fans in accordance with Section 403.4.6.1 to meet the pressure equalization requirements of Section 501.4. The flow rate for the outdoor air intake must be tested and verified at the minimum ventilation fan speed and the maximum heating or cooling fan speed. The results of the test shall be submitted and posted in accordance with Section 403.4.6.7.

403.4.6.5 Intermittent off operation. Whole house mechanical ventilation systems shall be provided with advanced controls that are configured to operate the system with intermittent off operation and shall operate for a least two hours in each four-hour segment. The whole house ventilation airflow rate determined in accordance with Section 403.4.2 as corrected by Section 403.4.3 shall be multiplied by the factor determined in accordance with Table 403.4.6.5.

Table 403.4.6.5

**INTERMITTENT WHOLE HOUSE MECHANICAL VENTILATION RATE
FACTORS^{a, b}**

Run-time Percentage in Each 4-hour Segment	50%	66%	75%	100%
Factor ^a	2	1.5	1.3	1.0

- a For ventilation system run-time values between those given, the factors are permitted to be determined by interpolation.
- b Extrapolation beyond the table is prohibited.

403.4.6.6 Testing. Whole house mechanical ventilation systems shall be tested, balanced and verified to provide a flow rate not less than the minimum required by Sections 403.4.2 and 403.4.3. Testing shall be performed according to the ventilation equipment manufacturer's instructions, or by using a flow hood, flow grid, or other airflow measuring device at the mechanical ventilation fan's inlet terminals, outlet terminals or grilles or in the connected ventilation ducts. Where required by the building official, testing shall be conducted by an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the building official and shall be posted in the residential unit in accordance with Section 403.4.6.7.

403.4.6.7 Certificate. A permanent certificate shall be completed by the mechanical contractor, test and balance contractor or other approved party and posted on a wall in the space where the furnace is located, a utility room, or an *approved* location inside the building. When located on an electrical panel, the certificate shall not cover or obstruct the visibility of the circuit directory label, service disconnect label, or other required labels. The certificate shall list the flow rate determined from the delivered airflow of the whole house mechanical ventilation system as installed and the type of mechanical whole house ventilation system used to comply with Section 403.4.3.

403.4.7 Local exhaust. Bathrooms, toilet rooms and kitchens shall include a local exhaust system. Such local exhaust systems shall have the capacity to exhaust the minimum airflow rate in accordance with Table 403.4.7 and Table 403.3.1.1, including notes. Fans required by this section shall be provided with controls that enable manual override or automatic occupancy sensor, humidity sensor, timer controls, or pollutant sensor controls. An "on/off" switch shall meet this requirement for manual controls. Manual fan controls shall be provided with ready access in the room served by the fan.

Table 403.4.7
MINIMUM EXHAUST RATES

Area to be exhausted	Exhaust Rate	
	Intermittent	Continuous
Open kitchens	In accordance with Section 403.4.7.3	Not permitted
Enclosed kitchens	In accordance with Section 403.4.7.3	5 ACH based on kitchen volume
Bathrooms - Toilet rooms	50 cfm	20 cfm

403.4.7.1 Whole house exhaust controls. If the local exhaust fan is included in a whole house ventilation system in accordance with Section 403.4.6, the exhaust fan shall be controlled to operate as specified in Section 403.4.5.

403.4.7.2 Local exhaust fans. Exhaust fans shall meet the following criteria.

1. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920 or equivalent.

2. Fan airflow rating and duct system shall be designed and installed to deliver at least the exhaust airflow required by Table 403.4.7. The airflows required refer to the delivered airflow of the system as installed and tested using a flow hood, flow grid, or other airflow measurement device. Local exhaust systems shall be tested and verified to provide a flow rate not less than the minimum required by this section.

3. Design and installation of the system or equipment shall be carried out in accordance with manufacturers' installation instructions.

4. Intermittent local exhaust system serving kitchens shall be rated for sound at a maximum of 3 sones at one or more airflow settings not less than 100 cfm at a static pressure not less than that determined at working speed as specified in HVI 916 Section 7.2.

5. Continuous local exhaust system serving kitchens shall be rated for sound at a maximum of 1 sone at one or more airflow settings not less than 100 cfm at a static pressure not less than that determined at working speed as specified in HVI 916 Section 7.2.

- EXCEPTIONS:
1. The installed airflow is not required to be field-verified where an exhaust airflow rating at a pressure of 0.25 in. w.g. may be used, provided the duct sizing meets the prescriptive requirements of Table 403.4.7.2.
 2. Remote mounted fans need not meet sound requirements. To be considered for this exception, a remote mounted fan shall be mounted outside the kitchen, and there shall be at least 4 feet (1 m) of ductwork between the fan and the intake grille.

Table 403.4.7.2
PRESCRIPTIVE EXHAUST DUCT SIZING

Fan Tested cfm at 0.25 inches w.g.	Minimum Flex Diameter	Maximum Length in Feet	Minimum Smooth Diameter	Maximum Length in Feet	Maximum Elbows ^a
50	4 inches	25	4 inches	70	3
50	5 inches	90	5 inches	100	3
50	6 inches	No Limit	6 inches	No Limit	3
80	4 inches ^b	NA	4 inches	20	3
80	5 inches	15	5 inches	100	3
80	6 inches	90	6 inches	No Limit	3
100	5 inches ^b	NA	5 inches	50	3
100	6 inches	45	6 inches	No Limit	3
125	6 inches	15	6 inches	No Limit	3
125	7 inches	70	7 inches	No Limit	3

- a. For each additional elbow, subtract 10 feet from length.
- b. Flex ducts of this diameter are not permitted with fans of this size.

403.4.7.3 Local intermittent kitchen exhaust system. Kitchen range hoods for domestic cooking appliances shall meet or exceed either the minimum airflow or the minimum capture efficiency in accordance with Table 403.4.7.3. Capture efficiency ratings shall be determined in accordance with ASTM E3087.

EXCEPTION: Other intermittent kitchen exhaust fans, including downdraft, shall meet or exceed 300 cfm airflow.

Table 403.4.7.3

**Kitchen Range Hood Airflow Rates
(CFM) and ASTM E3087 Capture Efficiency (CE) Ratings According to
Kitchen Range Fuel Type**

Hood Over Electric Range	Hood Over Combustion Range
65 percent CE or 160 cfm	80 percent CE or 250 cfm

403.4.7.3.1 Field verification and diagnostic testing for local intermittent kitchen exhaust system. The local exhaust system for kitchens shall be installed to comply with local mechanical exhaust requirements specified in 403.4.7.3 and shall be field verified in accordance with the procedures below to confirm the model is rated by HVI or AHAM to comply with the following requirements:

1. Local intermittent exhaust system for kitchens shall be tested and verified to provide a minimum airflow rate or capture efficiency required by Section 403.4.7.3. Testing shall include verification of the maximum sound rating as specified in Section 403.4.7.2. Testing for the intermittent kitchen exhaust systems shall occur with the whole house ventilation system operating and with all dwelling unit or sleeping unit entry doors closed. Testing for exhaust systems that require mechanical makeup air in accordance with Section 505.4 shall include verifying that the mechanical makeup air opening is open. Testing for exhaust systems that require mechanical makeup air in accordance with Section 505.4 shall include verifying that the mechanical makeup air system is controlled to automatically start. Testing for exhaust systems that do not require mechanical makeup air in accordance with Section 505.4 and that are exempt from pressurize equalization per Section 501.4 shall be tested with operable openings manually opened unless design exhaust airflow can be achieved with all operable openings closed. Where required by the building official, testing shall be conducted by an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the building official.

EXCEPTION: The installed airflow is not required to be field-verified where an exhaust airflow rating at a pressure of 0.25 in. w.g. is used, provided the duct sizing meets the prescriptive requirements of Table 403.4.7.2.

2. The verification shall utilize certified rating data from *HVI Publication 911, AHAM-Certified Range Hood Directory*, or another directory of certified product performance ratings approved by the code official for determining compliance. The verification procedure shall consist of visual inspection of the local intermittent kitchen exhaust system to verify and record the following information:

2.1. The manufacturer name and model number.

2.2. The model is listed in the HVI, AHAM, or equivalent directory.

2.3. The rated airflow value listed in the HVI, AHAM, or equivalent directory.

2.4. The sound rating value listed in the HVI, AHAM, or equivalent directory.

2.5. If the value for the rated airflow given in the directory is greater than or equal to the airflow requirements specified in Section 403.4.7.3 and if the value for the sound rating given in the directory is less than or equal to the sound rating requirements specified in 403.4.7.2, then the local intermittent kitchen exhaust system complies, otherwise the local intermittent kitchen exhaust system does not comply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-02-055, 23-12-106, and 23-20-025, § 51-52-0403, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.031, 19.27.074, and chapter 19.27 RCW. WSR 22-09-009, § 51-52-0403, filed 4/8/22, effective 5/9/22. Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-05-020, § 51-52-0403, filed 2/8/21, effective 3/11/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-03-041, § 51-52-0403, filed 1/8/20, effective 7/1/20; WSR 17-10-075, § 51-52-0403, filed 5/3/17, effective 6/3/17; WSR 16-01-148, § 51-52-0403, filed 12/21/15, effective 7/1/16. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-053, § 51-52-0403, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031, 19.27.035, 19.27.074, and chapters 19.27 and 34.05 RCW. WSR 12-07-020, § 51-52-0403, filed 3/12/12, effective 4/12/12. Statutory Authority: RCW 19.27.190, 19.27.074, 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 10-03-099, § 51-52-0403, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.190, 19.27.020, and chapters 19.27 and 34.05 RCW. WSR 07-01-092, § 51-52-0403, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 05-01-015, § 51-52-0403, filed 12/2/04, effective 7/1/05.]

Reviser's note: The brackets and enclosed material in the text of the above section occurred in the copy filed by the agency.

(Effective March 16, 2024)

WAC 51-52-0403 Section 403—Mechanical ventilation.

403.1 Ventilation system. Mechanical ventilation shall be provided by a method of supply air and return or *exhaust air*. The amount of supply air shall be approximately equal to the amount of return and *exhaust air*. The system shall not be prohibited from producing negative or positive pressure. The system to convey ventilation air shall be designed and installed in accordance with Chapter 6.

403.2 Outdoor air required. The minimum *outdoor airflow rate* shall be determined in accordance with Section 403.3.

EXCEPTIONS: 1. Where the registered design professional demonstrates that an engineered ventilation system design will prevent the maximum concentration of contaminants from exceeding that obtainable by the rate of *outdoor air* ventilation determined in accordance with Section 403.3, the minimum required rate of *outdoor air* shall be reduced in accordance with such engineered system design.
2. Alternate systems designed in accordance with ASHRAE Standard 62.1 Section 6.2, Ventilation Rate Procedure, shall be permitted.

403.2.1 Recirculation of air. The air required by Section 403.3 shall not be recirculated. Air in excess of that required by Section 403.3 shall not be prohibited from being recirculated as a component of supply air to building spaces, except that:

1. Ventilation air shall not be recirculated from one dwelling to another or to dissimilar occupancies.

2. Supply air to a swimming pool and associated deck areas shall not be recirculated unless such air is dehumidified to maintain the relative humidity of the area at 60 percent or less. Air from this area shall not be recirculated to other spaces where 10 percent or more of the resulting supply airstream consists of air recirculated from these spaces. The design and installation of dehumidification systems shall comply with ANSI/ACCA 10 Manual SPS.

3. Where mechanical exhaust is required by Note b in Table 403.3.1.1, recirculation of air from such spaces shall be prohibited.

All air supplied to such spaces shall be exhausted, including any air in excess of that required by Table 403.3.1.1.

4. Where mechanical exhaust is required by Note g in Table 403.3.1.1, mechanical exhaust is required and recirculation from such spaces is prohibited where more than 10 percent of the resulting supply airstream consists of air recirculated from these spaces. Recirculation of air that is contained completely within such spaces shall not be prohibited.

403.3 Outdoor air and local exhaust airflow rates. Group R occupancies shall be provided with outdoor air and local exhaust in accordance with Section 403.4. All other buildings intended to be occupied shall be provided with outdoor air and local exhaust in accordance with Section 403.3.1.

403.3.1.1 Outdoor airflow rate. Ventilation systems shall be designed to have the capacity to supply the minimum outdoor airflow rate determined in accordance with this section. In each occupiable space, the ventilation system shall be designed to deliver the required rate of outdoor airflow to the breathing zone. Outdoor air shall be supplied directly to each occupiable space from an air handling unit through a fully ducted path or ducted to within 12 inches of the return air opening of a fan-powered terminal unit used to transfer the outdoor air to the occupiable space. The occupant load utilized for design of the ventilation system shall not be less than the number determined from the estimated maximum occupant load rate indicated in Table 403.3.1.1. Ventilation rates for occupancies not represented in Table 403.3.1.1 shall be those for a listed occupancy classification that is most similar in terms of occupant density, activities and building construction; or shall be determined by an approved engineering analysis. The ventilation system, including transfer fan-powered terminal units, shall be designed to supply the required rate of ventilation air continuously during the period the building is occupied, except as otherwise stated in other provisions of the code.

With the exception of smoking lounges, the ventilation rates in Table 403.3.1.1 are based on the absence of smoking in occupiable spaces. Where smoking is anticipated in a space other than a smoking lounge, the ventilation system serving the space shall be designed to provide ventilation over and above that required by Table 403.3.1.1 in accordance with accepted engineering practice.

EXCEPTION: Where occupancy density is known and documented in the plans, the outside air rate may be based on the design occupant density. Under no circumstance shall the occupancies used result in outside air less than one-half that resulting from application of Table 403.3.1.1 estimated maximum occupancy rates.

Table 403.3.1.1
REQUIRED OUTDOOR VENTILATION AIR

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone <i>R_p</i> cfm/Person	Area Outdoor Airflow Rate in Breathing Zone <i>R_a</i> cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Correctional facilities				
Booking/waiting	50	7.5	0.06	—
Cells				
Without plumbing fixtures	25	5	0.12	—
With plumbing fixtures ^b	25	5	0.12	1.0
Day room	30	5	0.06	—
Dining halls	—	—	—	—
(see "Food and beverage service")	—	—	—	—

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Guard stations	15	5	0.06	—
Dry cleaners, laundries				
Coin-operated dry cleaner	20	15	—	—
Coin-operated laundries	20	7.5	0.12	—
Commercial dry cleaner	30	30	—	—
Commercial laundry	10	5	0.12	—
Storage, pick up	30	7.5	0.12	—
Education				
Art classroom ^g	20	10	0.18	0.7
Auditoriums	150	5	0.06	—
Classrooms (ages 5 through 8)	25	10	0.12	—
Classrooms (age 9 plus)	35	10	0.12	—
Computer lab	25	10	0.12	—
Corridors (see "Public spaces")	—	—	—	—
Day care (through age 4)	25	10	0.18	—
Lecture classroom	65	7.5	0.06	—
Lecture hall (fixed seats)	150	7.5	0.06	—
Locker/dressing rooms ^g	—	—	—	0.25
Media center	25	10	0.12	—
Multiuse assembly	100	7.5	0.06	—
Music/theater/dance	35	10	0.06	—
Science laboratories ^g	25	10	0.18	1.0
Smoking lounges ^b	70	60	—	—
Sports locker rooms ^g	—	—	—	0.5
Wood/metal shops ^g	20	10	0.18	0.5
Food and beverage service				
Bars, cocktail lounges	100	7.5	0.18	—
Cafeteria, fast food	100	7.5	0.18	—
Dining rooms	70	7.5	0.18	—
Kitchens (cooking) ^b	20	7.5	0.12	0.7
Hotels, motels, resorts, and dormitories				
Bathrooms/toilets—private ^g	—	—	—	25/50 ^f
Bedroom/living room	10	5	0.06	—
Conference/meeting	50	5	0.06	—
Dormitory sleeping area	20	5	0.06	—
Gambling casinos	120	7.5	0.18	—
Lobbies/prefunction	30	7.5	0.06	—
Multipurpose assembly	120	50	0.06	—
Offices				
Conference rooms	50	5	0.06	—
Kitchenettes ^k	25	5	0.06	0.30
Office spaces	5	5	0.06	—
Reception areas	30	5	0.06	—
Telephone/data entry	60	5	0.06	—
Main entry lobbies	10	5	0.06	—
Private dwellings, single and multiple				
Garages, common for multiple units ^b	—	—	—	0.75
Kitchens ^b	—	—	—	See Table 403.4.7
Living areas ^c	—	See Table 403.4.2	—	—
Toilet rooms and bathrooms ^g	—	—	—	See Table 403.4.7

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Public spaces				
Corridors serving other than Group R occupancies	—	—	0.06	—
Corridors serving Group R dwelling or sleeping units with whole house exhaust system	—	—	0.12	—
Corridors serving Group R dwelling or sleeping units with other than whole house exhaust system	—	—	0.06	—
Courtrooms	70	5	0.06	—
Elevator car	—	—	—	1.0
Elevator lobbies in parking garage	—	—	1.0	—
Legislative chambers	50	5	0.06	—
Libraries	10	5	0.12	—
Museums (children's)	40	7.5	0.12	—
Museums/galleries	40	7.5	0.06	—
Places of religious worship	120	5	0.06	—
Shower room (per showerhead) ^g	—	—	—	50/20 ^f
Smoking lounges ^b	70	60	—	—
Toilet rooms—Public ^g	—	—	—	50/70 ^e
Retail stores, sales floors, and showroom floors				
Dressing rooms	—	—	—	0.25
Mall common areas	40	7.5	0.06	—
Sales	15	7.5	0.12	—
Shipping and receiving	2	10	0.12	—
Smoking lounges ^b	70	60	—	—
Storage rooms	—	—	0.12	—
Warehouses (see "Storage")	—	10	0.06	—
Specialty shops				
Automotive motor fuel-dispensing stations ^b	—	—	—	1.5
Barber	25	7.5	0.06	0.5
Beauty salons ^b	25	20	0.12	0.6
Embalming rooms ^b	—	—	—	2.0
Nail salons ^{b,h}	25	20	0.12	0.6
Pet shops (animal areas) ^b	10	7.5	0.18	0.9
Supermarkets	8	7.5	0.06	—
Sports and amusement				
Disco/dance floors	100	20	0.06	—
Bowling alleys (seating areas)	40	10	0.12	—
Game arcades	20	7.5	0.18	—
Ice arenas, without combustion engines ^j	—	—	0.30	0.5
Gym, stadium, arena (play area) ^j	7	20	0.18	—
Spectator areas	150	7.5	0.06	—
Swimming pools (pool and deck area)	—	—	0.48	—
Health club/aerobics room	40	20	0.06	—
Health club/weight room	10	20	0.06	—
Storage				
Janitor closets, trash rooms, recycling rooms	—	—	—	1.0
Repair garages, enclosed parking garage ^{b, d}	—	—	—	0.75
Storage rooms, chemical	—	—	—	1.5
Warehouses	—	—	0.06	—

Occupancy Classification	Occupant Density #/1000 ft ^{2a}	People Outdoor Airflow Rate in Breathing Zone R_p cfm/Person	Area Outdoor Airflow Rate in Breathing Zone R_a cfm/ft ^{2a}	Exhaust Airflow Rate cfm/ft ^{2a}
Theaters				
Auditoriums (see "Education")	—	—	—	—
Lobbies	150	5	0.06	—
Stages, studios	70	10	0.06	—
Ticket booths	60	5	0.06	—
Transportation				
Platforms	100	7.5	0.06	—
Transportation waiting	100	7.5	0.06	—
Workrooms				
Bank vaults/safe deposit	5	5	0.06	—
Darkrooms	—	—	—	1.0
Copy, printing rooms	4	5	0.06	0.5
Freezer and refrigerated spaces (<50°F)	0	10	0	0
Meat processing ^c	10	15	—	—
Pharmacy (prep. area)	10	5	0.18	—
Photo studios	10	5	0.12	—
Computer (without printing)	4	5	0.06	—

For SI: 1 cubic foot per minute = 0.0004719 m³/s, 1 ton = 908 kg, 1 cubic foot per minutes per square foot = 0.00508 m³/(s•m²), °C = [(°F) -32]/1.8, 1 square foot = 0.0929 m².

- a. Based upon *net occupiable floor area*.
- b. Mechanical exhaust required and the recirculation of air from such spaces is prohibited. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Item 3).
- c. Spaces unheated or maintained below 50°F are not covered by these requirements unless the occupancy is continuous.
- d. Ventilation systems in enclosed parking garages shall comply with Section 404.
- e. Rates are per water closet or urinal. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- f. Rates are per room unless otherwise indicated. The higher rate shall be provided where the exhaust system is designed to operate intermittently. The lower rate shall be permitted only where the exhaust system is designed to operate continuously while occupied.
- g. Mechanical exhaust is required and recirculation from such spaces is prohibited. For occupancies other than science laboratories, where there is a wheel-type energy recovery ventilation (ERV) unit in the exhaust system design, the volume of air leaked from the exhaust airstream into the outdoor airstream within the ERV shall be less than 10 percent of the outdoor air volume. Recirculation of air that is contained completely within such spaces shall not be prohibited (see Section 403.2.1, Items 2 and 4).
- h. For nail salons, each manicure and pedicure station shall be provided with a *source capture system* capable of exhausting not less than 50 cfm per station. Exhaust inlets shall be located in accordance with Section 502.20. Where one or more required source capture systems operate continuously during occupancy, the exhaust rate from such systems shall be permitted to be applied to the exhaust flow rate required by Table 403.3.1.1 for the nail salon.
- i. Reserved.
- j. When combustion equipment is intended to be used on the playing surface, additional dilution ventilation and/or source control shall be provided.
- k. Kitchenettes require exhaust when they contain a domestic cooking appliance range or oven that is installed in accordance with Table 507.1.2. Kitchenettes that only contain a microwave cooking appliance are not required to have exhaust. A kitchenette may not contain commercial cooking appliances that require Type I or Type II exhaust as these occupancies are required to be exhausted to the kitchen category in Table 403.3.1.1.

403.3.1.1.2.3 Multiple zone recirculating systems. For ventilation systems wherein one or more air handlers supply a mixture of outdoor air and recirculated air to more than one ventilation zone, the outdoor air intake flow (V_{ot}) shall be determined in accordance with Sections 403.3.1.1.2.3.1 through 403.3.1.1.2.3.4.

403.3.1.1.2.3.1 Uncorrected outdoor air intake. The uncorrected outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-5.

$$V_{ou} = D \sum_{all\ zones} (R_p \times P_z) + \sum_{all\ zones} (R_a \times A_z) \quad \text{(Equation 4-5)}$$

403.3.1.1.2.3.1.1 Occupant diversity. The occupant diversity ratio (D) shall be determined in accordance with Equation 4-6 to account for variations in population within the ventilation zones served by the system.

$$D = P_s / \sum_{all\ zones} P_z \quad \text{(Equation 4-6)}$$

where:

P_s = System population: The total population in the area served by the system.

EXCEPTION: Alternative methods to account for occupant diversity shall be permitted, provided the resulting V_{ou} value is no less than that determined using Equation 4-5.

403.3.1.1.2.3.1.2 Design system population. Design system population (P_s) shall equal the largest (peak) number of people expected to occupy all ventilation zones served by the ventilation system during use.

Note: Design system population is always equal to or less than the sum of design zone population for all zones in the area served by the system because all zones may or may not be simultaneously occupied at design population.

403.3.1.1.2.3.2 System ventilation efficiency. The system ventilation efficiency (E_v) shall be determined in accordance with Section 403.3.1.1.2.3.3 for the Simplified Procedure or Appendix A of ASHRAE 62.1 for the Alternative Procedure.

Note: These procedures also establish zone minimum primary airflow rates for VAV systems.

403.3.1.1.2.3.3 Simplified procedure.

403.3.1.1.2.3.3.1 System ventilation efficiency. System ventilation efficiency (E_v) shall be determined in accordance with Equation 4-6a or 4-6b.

$$E_v = 0.88 \times D + 0.22 \text{ for } D < 0.60 \text{ (Equation 4-6a)}$$

$$E_v = 0.75 \text{ for } D \geq 0.60 \text{ (Equation 4-6b)}$$

403.3.1.1.2.3.3.2 Zone minimum primary airflow. For each zone, the minimum primary airflow (V_{pz-min}) shall be determined in accordance with Equation 4-7.

$$V_{pz-min} = V_{oz} \times 1.5 \text{ (Equation 4-7)}$$

403.3.1.1.2.3.4 Outdoor air intake. The design outdoor air intake flow (V_{ot}) shall be determined in accordance with Equation 4-8.

$$V_{ot} = V_{ou}/E_v \text{ (Equation 4-8)}$$

403.3.2 Group R-2, R-3 and R-4 occupancies. This section is not adopted. See Section 403.4.

403.3.2.1 Outdoor air for dwelling units. This section is not adopted.

403.3.2.2 Outdoor air for other spaces. This section is not adopted.

403.3.2.3 Local exhaust. This section is not adopted.

403.3.2.4 System controls. This section is not adopted.

403.4 Group R whole house mechanical ventilation system. Each dwelling unit or sleeping unit shall be equipped with a whole house mechanical ventilation system that complies with Sections 403.4.1 through 403.4.6. Each dwelling unit or sleeping unit shall be equipped with local exhaust complying with Section 403.4.7. All occupied spaces, including public corridors, other than the Group R dwelling units and/or sleeping units, that support these Group R occupancies shall meet the natural ventilation requirements of Section 402 or the mechanical ventilation requirements of Sections 403.1 through 403.3.

EXCEPTION: Alternate balanced whole house ventilation systems and local exhaust systems subject to the Washington State Energy Code, Residential Provisions serving Group R dwelling units designed and commissioned in accordance with ASHRAE Standard 62.2 are permitted.

403.4.1 System design. The whole house ventilation system shall consist of one or more supply fans, one or more exhaust fans, or an ERV/HRV with integral fans; and the associated ducts and controls. Local exhaust fans shall be permitted to serve as part of the whole house ventilation system when provided with the proper controls in accordance with Section 403.4.5. The systems shall be designed and installed to supply and exhaust the minimum outdoor airflow rates in accordance with Section 403.4.2 as corrected by the balanced and/or distributed whole house ventilation system coefficients in accordance with Section 403.4.3 where applicable.

Table 403.4.2
WHOLE HOUSE MECHANICAL VENTILATION AIRFLOW RATE
(CONTINUOUSLY OPERATING SYSTEMS)

Floor Area (ft ²)	Bedrooms ^a				
	1	2	3	4	>5
<500	30	30	35	45	50
500 - 1000	30	35	40	50	55
1001 - 1500	30	40	45	55	60
1501 - 2000	35	45	50	60	65
2001 - 2500	40	50	55	65	70
2501 - 3000	45	55	60	70	75
3001 - 3500	50	60	65	75	80
3501 - 4000	55	65	70	80	85
4001 - 4500	60	70	75	85	90
4501 - 5000	65	75	80	90	95

^a Minimum airflow (Q_r) is set at not less than 30 cfm for each dwelling units.

403.4.2 Whole house mechanical ventilation rates. The sleeping unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates minimum outdoor airflow rate shall be determined in accordance with the breathing zone ventilation rates requirements of Section 403.3.1.1.1.2 using Equation 4-2. The dwelling unit whole house mechanical ventilation minimum outdoor airflow rate shall be determined in accordance with Equation 4-10 or Table 403.4.2.

$$Q_r = 0.01 * A_{\text{floor}} + 7.5 * (N_{\text{br}} + 1) \quad \text{(Equation 4-10)}$$

where:

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) but not less than 30 cfm for each dwelling unit.

A_{floor} = Conditioned floor area, square feet (ft²)

N_{br} = Number of bedrooms, not less than one.

Table 403.4.3
SYSTEM COEFFICIENT (C_{system})

System Type	Distributed	Not Distributed
Balanced	1.0	1.25
Not Balanced	1.25	1.5

403.4.3 Ventilation quality adjustment. The minimum whole house ventilation rate from Section 403.4.2 shall be adjusted by the system coef-

efficient in Table 403.4.3 based on the system type not meeting the definition of a *balanced whole house ventilation system* and/or not meeting the definition of a *distributed whole house ventilation system*.

$$Q_v = Q_r * C_{\text{system}} \quad (\text{Equation 4-11})$$

where:

Q_v = Quality-adjusted ventilation airflow rate in cubic feet per minute (cfm)

Q_r = Ventilation airflow rate, cubic feet per minute (cfm) from Equation 4-10 or Table 403.4.2

C_{system} = System coefficient from Table 403.4.3

403.4.4 Whole house ventilation residential occupancies. Residential dwelling and sleeping unit whole house ventilation systems shall meet the requirements of Sections 403.4.4.1 or 403.4.4.2 depending on the occupancy of the residential unit.

403.4.4.1 Whole house ventilation in Group R-2 occupancies. Residential dwelling and sleeping units in Group R-2 occupancies system shall include supply and exhaust fans and be a *balanced whole house ventilation system* in accordance with Section 403.4.6.3. The system shall include a heat or energy recovery ventilator with a sensible heat recovery effectiveness as prescribed in Section C403.3.6 or when selected as an option of R406 of the *Washington State Energy Code*. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

EXCEPTIONS:

1. *Interior adjoining spaces* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the adjoining space. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3.
2. *Interior adjacent rooms* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the *interior adjacent room*. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3. The interior adjacent room shall be provided with a transfer fan with a minimum airflow rate of 30 cfm or with relief air inlet with a minimum airflow of 20 cfm that is connected to the exhaust/relief air inlet of an ERV/HRV whole house ventilation system. Transfer fans that ventilate *interior adjacent rooms* shall meet the same rating in Section 403.4.6 and shall have whole house ventilation controls in accordance with Section 403.4.5.

403.4.4.2 Whole house ventilation for other than Group R-2 occupancies. Residential dwelling and sleeping units in other than Group R-2 occupancies, including I-1 condition 2 occupancies, shall have a whole house mechanical ventilation system with supply and exhaust fans in accordance with Section 403.4.6.1, 403.4.6.2, 403.4.6.3, or 403.4.6.4. The whole house ventilation system shall operate continuously at the minimum ventilation rate determined in accordance with Section 403.4.2 unless configured with intermittent off controls in accordance with Section 403.4.6.5. The whole house supply fan shall provide ducted outdoor ventilation air to each habitable space within the residential unit.

EXCEPTIONS:

1. *Interior adjoining spaces* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the adjoining space. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3.
2. *Interior adjacent rooms* that are ventilated from another habitable space are not required to have outdoor air ducted directly to the *interior adjacent room*. These systems are considered *not distributed whole house ventilation systems* and shall use the "not distributed" quality adjustment system coefficient in accordance with Section 403.4.3. The interior adjacent room shall be provided with a transfer fan with a minimum airflow rate of 30 cfm or with relief air inlet with a minimum airflow of 20 cfm that is connected to the exhaust/relief air inlet of an ERV/HRV whole house ventilation system. Transfer fans that ventilate *interior adjacent rooms* shall meet the same rating in Section 403.4.6 and shall have whole house ventilation controls in accordance with Section 403.4.5.

403.4.5 Whole house ventilation controls.

1. The whole house ventilation system shall be controlled with manual switches, timers or other means that provide for automatic operation of the ventilation system that are readily accessible by the occupant;

2. Whole house mechanical ventilation system shall be provided with controls that enable manual override off of the system by the occupant during periods of poor outdoor air quality. Controls shall include permanent text or a symbol indicating their function. Recommended control permanent labeling to include text similar to the following: "Leave on unless outdoor air quality is very poor." Manual controls shall be provided with ready access for the occupant.

EXCEPTION: Central whole house mechanical systems with supply air and/or exhaust that serve more than one dwelling or sleep units are not required to have manual override off controls accessible to the occupant.

3. Whole house ventilation systems shall be configured to operate continuously except where intermittent off controls are provided in accordance with Section 403.4.6.5 and allowed by Section 403.4.4.2.

403.4.6 Whole house ventilation system component requirements. Whole house ventilation supply and exhaust fans specified in this section shall have a minimum efficacy as prescribed in the *Washington State Energy Code*. The fans shall be rated for sound at a maximum of 1.0 sone at design airflow and static pressure conditions. Design and installation of the system or equipment shall be carried out in accordance with manufacturer's installation instructions.

EXCEPTIONS: 1. Central supply or exhaust fans serving multiple residential units do not need to comply with the maximum fan sone requirements.
2. Interior joining spaces provided with a 30 cfm transfer fan or a 25 square foot permanent opening do not require supply ventilation air directly to the space. Transfer fans shall meet the sone rating above and have whole house ventilation controls in accordance with Section 403.4.5.

403.4.6.1 Exhaust fans. Exhaust fans required shall be ducted directly to the outside in accordance with Section 501.3. Exhaust air outlets shall be designed to limit the pressure difference to the outside to limiting the outlet free area maximum velocity to 500 feet per minute and equipped with backdraft dampers or motorized dampers in accordance with *Washington State Energy Code*. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Exhaust fans required in this section may be used to provide local ventilation. Exhaust fans serving spaces other than kitchens that are designed for intermittent exhaust rates in Table 403.4.7 shall be provided with occupancy sensors, humidity sensors, timer controls, or pollutant sensor controls to automatically override the fan to the high speed airflow rate. The exhaust fans shall be tested and the testing results shall be submitted and posted in accordance with Section 403.4.6.7.

EXCEPTIONS: 1. Central exhaust fans serving multiple residential units do not need to comply with the HVI testing requirements.
2. Inlet free area maximum velocity may exceed 500 feet per minute when a factory-built combined exhaust/intake termination fitting is used.

403.4.6.2 Supply fans. Supply fans used in meeting the requirements of this section shall supply outdoor air from intake openings in accordance with Sections 401.4 and 401.5. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 feet per minute and when designed for intermittent off operation shall be equipped with motorized dampers in accordance with the *Washington State Energy Code*. Supply fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920. Where outdoor air is provided to each habitable dwelling unit or sleeping unit by supply fan systems the outdoor air shall be filtered. The filter shall be provided with access for regular maintenance.

nance and replacement. The filter shall have a Minimum Efficiency Rating Value (MERV) of at least 8.

EXCEPTION: Central supply fans serving multiple residential units do not need to comply with the HVI testing requirements.

403.4.6.3 Balanced whole house ventilation system. A balanced whole house ventilation system shall include both supply and exhaust fans. The supply and exhaust fans shall have airflow that is within 10 percent of each other. The tested and balanced total mechanical exhaust airflow rate is within 10 percent or 5 cfm, whichever is greater, of the total mechanical supply airflow rate. The flow rate test results shall be submitted and posted in accordance with Section 403.4.6.7. The exhaust fan shall meet the requirements of Section 403.4.6.1. The supply fan shall meet the requirements of Section 403.4.6.2. For Group R-2 dwelling and sleeping units, the system is required to have balanced whole house ventilation but is not required to have distributed whole house ventilation where the not distributed system coefficient from Table 403.4.3 is utilized to correct the whole house mechanical ventilation rate. The system shall be designed and balanced to meet the pressure equalization requirements of Section 501.4. Local exhaust systems that are not a component of the whole-house mechanical ventilation system are exempt from the balanced airflow calculation.

403.4.6.4 Furnace integrated supply. Systems using space condition heating and/or cooling air handler fans for outdoor air supply air distribution are not permitted.

EXCEPTION: Air handler fans shall be permitted that have multi-speed or variable speed supply airflow control capability with a low speed operation not greater than 25 percent of the rated supply air flow capacity during ventilation only operation. Outdoor air intake openings must meet the provisions of Sections 401.4 and 401.5 and must include a motorized damper that is activated by the whole house ventilation system controller. Intake air openings shall be designed to limit the pressure difference to the outside to limiting the inlet free area maximum velocity to 500 ft per min. The motorized damper must be controlled to maintain the outdoor airflow intake airflow within 10 percent of the whole house mechanical exhaust airflow rate. The supply air handler shall provide supply air to each habitable space in the residential unit. The whole house ventilation system shall include exhaust fans in accordance with Section 403.4.6.1 to meet the pressure equalization requirements of Section 501.4. The flow rate for the outdoor air intake must be tested and verified at the minimum ventilation fan speed and the maximum heating or cooling fan speed. The results of the test shall be submitted and posted in accordance with Section 403.4.6.7.

403.4.6.5 Intermittent off operation. Whole house mechanical ventilation systems shall be provided with advanced controls that are configured to operate the system with intermittent off operation and shall operate for a least two hours in each four-hour segment. The whole house ventilation airflow rate determined in accordance with Section 403.4.2 as corrected by Section 403.4.3 shall be multiplied by the factor determined in accordance with Table 403.4.6.5.

Table 403.4.6.5

INTERMITTENT WHOLE HOUSE MECHANICAL VENTILATION RATE FACTORS^{a, b}

Run-time Percentage in Each 4-hour Segment	50%	66%	75%	100%
Factor ^a	2	1.5	1.3	1.0

^a For ventilation system run-time values between those given, the factors are permitted to be determined by interpolation.

^b Extrapolation beyond the table is prohibited.

403.4.6.6 Testing. Whole house mechanical ventilation systems shall be tested, balanced and verified to provide a flow rate not less than the minimum required by Sections 403.4.2 and 403.4.3. Testing shall be performed according to the ventilation equipment manufacturer's in-

structions, or by using a flow hood, flow grid, or other airflow measuring device at the mechanical ventilation fan's inlet terminals, outlet terminals or grilles or in the connected ventilation ducts. Where required by the building official, testing shall be conducted by an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the building official and shall be posted in the residential unit in accordance with Section 403.4.6.7.

403.4.6.7 Certificate. A permanent certificate shall be completed by the mechanical contractor, test and balance contractor or other approved party and posted on a wall in the space where the furnace is located, a utility room, or an approved location inside the building. When located on an electrical panel, the certificate shall not cover or obstruct the visibility of the circuit directory label, service disconnect label, or other required labels. The certificate shall list the flow rate determined from the delivered airflow of the whole house mechanical ventilation system as installed and the type of mechanical whole house ventilation system used to comply with Section 403.4.3.

403.4.7 Local exhaust. Bathrooms, toilet rooms and kitchens shall include a local exhaust system. Such local exhaust systems shall have the capacity to exhaust the minimum airflow rate in accordance with Table 403.4.7 and Table 403.3.1.1, including notes. Fans required by this section shall be provided with controls that enable manual override or automatic occupancy sensor, humidity sensor, timer controls, or pollutant sensor controls. An "on/off" switch shall meet this requirement for manual controls. Manual fan controls shall be provided with ready access in the room served by the fan.

Table 403.4.7
MINIMUM EXHAUST RATES

Area to be exhausted	Exhaust Rate	
	Intermittent	Continuous
Open kitchens	In accordance with Section 403.4.7.3	Not permitted
Enclosed kitchens	In accordance with Section 403.4.7.3	5 ACH based on kitchen volume
Bathrooms - Toilet rooms	50 cfm	20 cfm

403.4.7.1 Whole house exhaust controls. If the local exhaust fan is included in a whole house ventilation system in accordance with Section 403.4.6, the exhaust fan shall be controlled to operate as specified in Section 403.4.5.

403.4.7.2 Local exhaust fans. Exhaust fans shall meet the following criteria.

1. Exhaust fans shall be tested and rated in accordance with HVI 915, HVI 916, and HVI 920 or equivalent.

2. Fan airflow rating and duct system shall be designed and installed to deliver at least the exhaust airflow required by Table 403.4.7. The airflows required refer to the delivered airflow of the system as installed and tested using a flow hood, flow grid, or other airflow measurement device. Local exhaust systems shall be tested and

verified to provide a flow rate not less than the minimum required by this section.

3. Design and installation of the system or equipment shall be carried out in accordance with manufacturers' installation instructions.

4. Intermittent local exhaust system serving kitchens shall be rated for sound at a maximum of 3 sones at one or more airflow settings not less than 100 cfm at a static pressure not less than that determined at working speed as specified in HVI 916 Section 7.2.

5. Continuous local exhaust system serving kitchens shall be rated for sound at a maximum of 1 sone at one or more airflow settings not less than 100 cfm at a static pressure not less than that determined at working speed as specified in HVI 916 Section 7.2.

- EXCEPTIONS:
1. The installed airflow is not required to be field-verified where an exhaust airflow rating at a pressure of 0.25 in. w.g. may be used, provided the duct sizing meets the prescriptive requirements of Table 403.4.7.2.
 2. Remote mounted fans need not meet sound requirements. To be considered for this exception, a remote mounted fan shall be mounted outside the kitchen, and there shall be at least 4 feet (1 m) of ductwork between the fan and the intake grille.

Table 403.4.7.2
PRESCRIPTIVE EXHAUST DUCT SIZING

Fan Tested cfm at 0.25 inches w.g.	Minimum Flex Diameter	Maximum Length in Feet	Minimum Smooth Diameter	Maximum Length in Feet	Maximum Elbows ^a
50	4 inches	25	4 inches	70	3
50	5 inches	90	5 inches	100	3
50	6 inches	No Limit	6 inches	No Limit	3
80	4 inches ^b	NA	4 inches	20	3
80	5 inches	15	5 inches	100	3
80	6 inches	90	6 inches	No Limit	3
100	5 inches ^b	NA	5 inches	50	3
100	6 inches	45	6 inches	No Limit	3
125	6 inches	15	6 inches	No Limit	3
125	7 inches	70	7 inches	No Limit	3

- a. For each additional elbow, subtract 10 feet from length.
- b. Flex ducts of this diameter are not permitted with fans of this size.

403.4.7.3 Local intermittent kitchen exhaust system. Kitchen range hoods for domestic cooking appliances shall meet or exceed either the minimum airflow or the minimum capture efficiency in accordance with Table 403.4.7.3. Capture efficiency ratings shall be determined in accordance with ASTM E3087.

EXCEPTION: Other intermittent kitchen exhaust fans, including downdraft, shall meet or exceed 300 cfm airflow.

Table 403.4.7.3
Kitchen Range Hood Airflow Rates (CFM) and ASTM E3087 Capture Efficiency (CE) Ratings According to Kitchen Range Fuel Type

Hood Over Electric Range	Hood Over Combustion Range
65 percent CE or 160 cfm	80 percent CE or 250 cfm

403.4.7.3.1 Field verification and diagnostic testing for local intermittent kitchen exhaust system. The local exhaust system for kitchens shall be installed to comply with local mechanical exhaust requirements specified in Section 403.4.7.3 and shall be field verified in accordance with the procedures below to confirm the model is rated by HVI or AHAM to comply with the following requirements:

1. Local intermittent exhaust system for kitchens shall be tested and verified to provide a minimum airflow rate or capture efficiency required by Section 403.4.7.3. Testing shall include verification of the maximum sound rating as specified in Section 403.4.7.2. Testing for the intermittent kitchen exhaust systems shall occur with the whole house ventilation system operating and with all dwelling unit or sleeping unit entry doors closed. Testing for exhaust systems that require mechanical makeup air in accordance with Section 505.4 shall include verifying that the mechanical makeup air opening is open. Testing for exhaust systems that require mechanical makeup air in accordance with Section 505.4 shall include verifying that the mechanical makeup air system is controlled to automatically start. Testing for exhaust systems that do not require mechanical makeup air in accordance with Section 505.4 and that are exempt from pressurize equalization per Section 501.4 shall be tested with operable openings manually opened unless design exhaust airflow can be achieved with all operable openings closed. Where required by the building official, testing shall be conducted by an approved third party. A written report of the results of the test shall be signed by the party conducting the test and provided to the building official.

EXCEPTION: The installed airflow is not required to be field-verified where an exhaust airflow rating at a pressure of 0.25 in. w.g. is used, provided the duct sizing meets the prescriptive requirements of Table 403.4.7.2.

2. The verification shall utilize certified rating data from *HVI Publication 911*, *AHAM-Certified Range Hood Directory*, or another directory of certified product performance ratings approved by the code official for determining compliance. The verification procedure shall consist of visual inspection of the local intermittent kitchen exhaust system to verify and record the following information:

2.1. The manufacturer name and model number.

2.2. The model is listed in the HVI, AHAM, or equivalent directory.

2.3. The rated airflow value listed in the HVI, AHAM, or equivalent directory.

2.4. The sound rating value listed in the HVI, AHAM, or equivalent directory.

2.5. If the value for the rated airflow given in the directory is greater than or equal to the airflow requirements specified in Section 403.4.7.3 and if the value for the sound rating given in the directory is less than or equal to the sound rating requirements specified in Section 403.4.7.2, then the local intermittent kitchen exhaust system complies, otherwise the local intermittent kitchen exhaust system does not comply.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-105, § 51-52-0403, filed 11/15/23, effective 3/16/24; WSR 23-02-055, 23-12-106, and 23-20-025, § 51-52-0403, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27.031, 19.27.074, and chapter 19.27 RCW. WSR 22-09-009, § 51-52-0403, filed 4/8/22, effective 5/9/22. Statutory Authority: RCW 19.27.035 and 19.27.074. WSR 21-05-020, § 51-52-0403, filed 2/8/21, effective 3/11/21. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-03-041, § 51-52-0403, filed 1/8/20, effective 7/1/20; WSR 17-10-075, § 51-52-0403, filed 5/3/17, effective 6/3/17; WSR 16-01-148, § 51-52-0403, filed 12/21/15, effective 7/1/16. Statutory Authority: RCW 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 13-04-053, § 51-52-0403, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031, 19.27.035, 19.27.074, and chapters 19.27 and

34.05 RCW. WSR 12-07-020, § 51-52-0403, filed 3/12/12, effective 4/12/12. Statutory Authority: RCW 19.27.190, 19.27.074, 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 10-03-099, § 51-52-0403, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.190, 19.27.020, and chapters 19.27 and 34.05 RCW. WSR 07-01-092, § 51-52-0403, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.020, 19.27.031, 19.27.074 and chapters 19.27 and 34.05 RCW. WSR 05-01-015, § 51-52-0403, filed 12/2/04, effective 7/1/05.]

Reviser's note: The brackets and enclosed material in the text of the above section occurred in the copy filed by the agency.