

**(Effective March 15, 2024)**

**WAC 51-54A-0321 Artificial combustible vegetation.**

**321.1 Artificial combustible vegetation on roofs and near buildings.**

Artificial combustible vegetation exceeding 6 feet (1829 mm) in height and permanently installed outdoors within 5 feet (1524 mm) of a building or on the roof of a building shall comply with Section 807.4.1. The placement of artificial combustible vegetation shall also comply with Sections 806.3 and 807.4.2.

EXCEPTIONS:     1. Artificial decorative vegetation located more than 30 feet (9144 mm) from the exterior wall of a building.  
                  2. Artificial decorative vegetation used at structures regulated by the International Residential Code.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-0321, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]