

(Effective March 15, 2024)

WAC 51-54A-1006 Number of exits and exit access doorways.

1006.2.1 Egress based on occupant load and common path of egress travel distance. Two *exits* or *exit* access doorways from any space shall be provided where the design occupant load or the common path of egress travel distance exceeds the values listed in Table 1006.2.1. The cumulative *occupant load* from adjacent rooms, areas or spaces shall be determined in accordance with Section 1004.2.

EXCEPTIONS:

1. The number of *exits* from foyers, lobbies, vestibules or similar spaces need not be based on cumulative *occupant loads* for areas discharging through such spaces, but the capacity of the *exits* from such spaces shall be based on applicable cumulative occupant loads.
2. Care suites in Group I-2 occupancies complying with Section 407.4 of the *International Building Code*.
3. Unoccupied mechanical rooms and penthouses are not required to comply with the common path of egress travel distance measurement.
4. The common path of travel for fixed transit and passenger rail system stations shall be in accordance with Section 4901.

1006.2.1.1 Three or more exits or exit access doorways. Three *exits* or *exit* access doorways shall be provided from any space with an occupant load of 501 to 1,000. Four *exits* or *exit* access doorways shall be provided from any space with an occupant load greater than 1,000.

EXCEPTION: The number of required exits for fixed transit and passenger rail systems may be reduced by one at open stations.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1006, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]

(Effective March 16, 2024)

WAC 51-54A-1006 Number of exits and exit access doorways.

1006.2.1 Egress based on occupant load and common path of egress travel distance. Two *exits* or *exit* access doorways from any space shall be provided where the design occupant load or the common path of egress travel distance exceeds the values listed in Table 1006.2.1. The cumulative *occupant load* from adjacent rooms, areas or spaces shall be determined in accordance with Section 1004.2.

EXCEPTIONS:

1. The number of *exits* from foyers, lobbies, vestibules or similar spaces need not be based on cumulative *occupant loads* for areas discharging through such spaces, but the capacity of the *exits* from such spaces shall be based on applicable cumulative occupant loads.
2. Care suites in Group I-2 occupancies complying with Section 407.4 of the *International Building Code*.
3. Unoccupied mechanical rooms and penthouses are not required to comply with the common path of egress travel distance measurement.
4. The common path of travel for fixed transit and passenger rail system stations shall be in accordance with Section 4901.

1006.2.1.1 Three or more exits or exit access doorways. Three *exits* or *exit* access doorways shall be provided from any space with an occupant load of 501 to 1,000. Four *exits* or *exit* access doorways shall be provided from any space with an occupant load greater than 1,000.

EXCEPTION: The number of required exits for fixed transit and passenger rail systems may be reduced by one at open stations.

1006.3.4 Single exits. A single *exit* or *access* to a single *exit* shall be permitted from any story or occupied roof where one of the following conditions exists:

1. The *occupant load*, number of *dwelling units* and *exit access* travel distance within the portion of the building served by the single *exit* do not exceed the values in Table 1006.3.4(1) or 1006.3.4(2).

2. Rooms, areas and spaces complying with Section 1006.2.1 with *exits* that discharge directly to the exterior at the level of *exit discharge*, are permitted to have one *exit* or *access* to a single *exit*.

3. Parking garages where vehicles are mechanically parked shall be permitted to have one exit or access to a single exit.

4. Groups R-3 and R-4 occupancies shall be permitted to have one exit or access to a single exit.

5. Individual single-story or multistory dwelling units shall be permitted to have a single exit or access to a single exit from the dwelling unit provided that both of the following criteria are met:

5.1. The dwelling unit complies with Section 1006.2.1 as a space with one means of egress.

5.2. Either the exit from the dwelling unit discharges directly to the exterior at the level of exit discharge, or the exit access outside the dwelling unit's entrance door provides access to not less than two approved independent exits.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-106, § 51-54A-1006, filed 11/15/23, effective 3/16/24; WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-1006, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]