

**(Effective March 15, 2024)**

**WAC 51-54A-3311 Additional safeguards for Type I and II construction.**

**3311.1 Separations between construction areas.** Separations used in Type I and Type II construction to separate construction areas from occupied portions of the building shall be constructed of materials that comply with one of the following:

1. Noncombustible materials.
2. Materials that exhibit a flame spread index not exceeding 25 when tested in accordance with ASTM E84 or UL 723.
3. Materials exhibiting a peak heat release rate not exceeding 300 kW/m when tested in accordance with ASTM E1354 at an incident heat flux of 50 kW/m in the horizontal orientation on specimens at the thickness intended for use.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, 23-12-107, and 23-20-027, § 51-54A-3311, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24.]