

**WAC 246-215-06355 Service sinks—Availability (FDA Food Code 6-306.10).** A service sink or curbed cleaning facility must be provided as specified under WAC 246-215-05240.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-06355, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-06355, filed 1/17/13, effective 5/1/13.]