

**WAC 388-107-0970 Sinks—Water temperature.** The facility must provide all sinks in resident rooms, toilet rooms and bathrooms, and bathing fixtures used by residents with hot water between one hundred five degrees (105°) Fahrenheit and one hundred twenty degrees (120°) Fahrenheit at all times.

[Statutory Authority: Chapter 70.97 RCW. WSR 14-19-071, § 388-107-0970, filed 9/12/14, effective 10/13/14.]