

WAC 388-107-0990 Mechanical—Cooling systems. The facility must have:

(1) A mechanical cooling system capable of maintaining a temperature of seventy-five degrees Fahrenheit for areas occupied by residents; and

(2) A cooling system that has mechanical refrigeration equipment to provide summer air conditioning to resident areas, food preparation areas, laundry, medication rooms, and therapy areas by either a central system with distribution ducts or piping, or packaged room or zonal air conditioners.

[Statutory Authority: Chapter 70.97 RCW. WSR 14-19-071, § 388-107-0990, filed 9/12/14, effective 10/13/14.]