

WAC 296-307-45505 Additional safeguards when constructing dip tanks. (1) The employer must make sure the dip tank, drain boards (if provided), and supports are made of noncombustible material.

(2) The employer must make sure piping connections on drains and overflow pipes allow easy access to the inside of the pipe for inspection and cleaning.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 20-21-091, § 296-307-45505, filed 10/20/20, effective 11/20/20; WSR 03-10-068, § 296-307-45505, filed 5/6/03, effective 8/1/03.]