

WAC 388-833-0036 What water temperature safety measures must be met? (1) The provider must regulate the facility's water temperature no higher than 120 degrees Fahrenheit.
(2) The provider must complete and document monthly water temperature checks.

[Statutory Authority: RCW 71A.12.030, 71A.12.010, and 71A.12.120. WSR 24-19-101, s 388-833-0036, filed 9/18/24, effective 10/19/24.]