

RCW 70A.125.190 Measuring chlorine residuals. A group A water system serving fewer than one hundred connections that purchases water from a water system approved by the department shall measure chlorine residuals at the same time and location of collection for a routine and repeat coliform sample. [2009 c 367 s 8. Formerly RCW 70.119A.200.]