

WAC 480-93-186 Leak evaluation. (1) Based on an evaluation of the location and/or magnitude of a leak, the gas pipeline company must assign one of the leak grades defined in WAC 480-93-18601 to establish the leak repair priority. A gas pipeline company may use an alphabetical grade classification, i.e., Grade A for Grade 1, Grade B for Grade 2, and Grade C for Grade 3 if it has historically used such a grading designation. Each gas pipeline company must apply the same criteria used for initial leak grading when reevaluating leaks.

(2) Each gas pipeline company must establish a procedure for evaluating the concentration and extent of gas leakage. When evaluating any leak, the gas pipeline company must determine and document the perimeter of the leak area. If the perimeter of the leak extends to a building wall, the gas pipeline company must extend the investigation inside the building. Where the reading is in an unvented, enclosed space, the gas pipeline company must consider the rate of dissipation when the space is ventilated and the rate of accumulation when the space is resealed.

(3) The gas pipeline company must check the perimeter of the leak area with a combustible gas indicator. The gas pipeline company must perform a follow-up inspection on all leak repairs with residual gas remaining in the ground as soon as practical, but not later than thirty days following the repair.

(4) Grade 1 and 2 leaks can only be downgraded once to a Grade 3 leak without a physical repair. After a leak has been downgraded once, the maximum repair time for that leak is twenty-one months.

[Statutory Authority: RCW 80.01.040, 80.04.060 and 81.88.040. WSR 08-12-046 (Docket PG-070975, General Order R-549), § 480-93-186, filed 5/30/08, effective 6/30/08. Statutory Authority: RCW 80.04.160, 80.28.210, and 80.01.040. WSR 05-10-055 (Docket No. UG-011073, General Order No. R-520), § 480-93-186, filed 5/2/05, effective 6/2/05; Order R-103, § 480-93-186, filed 5/18/77.]