

***(Effective until February 1, 2021)***

**WAC 51-11C-40511 Section C405.11—Voltage drop in feeders and branch circuits.**

**Voltage drop in feeders and branch circuits.** The total voltage drop across the combination of feeders and branch circuits shall not exceed five percent.

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and Chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40511, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-24-070, § 51-11C-40511, filed 12/6/16, effective 5/1/17. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40511, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40511, filed 2/1/13, effective 7/1/13.]

***(Effective February 1, 2021)***

**WAC 51-11C-40511 Section C405.11—Voltage drop in feeders and branch circuits.**

**C405.11 Voltage drop in feeders and branch circuits.** The total voltage drop across the combination of feeders and branch circuits shall not exceed five percent.

[Statutory Authority: RCW 19.27A.025, 19.27A.045 and chapter 19.27 RCW. WSR 20-21-080, § 51-11C-40511, filed 10/19/20, effective 2/1/21. Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and Chapter 19.27 RCW. WSR 19-24-040, § 51-11C-40511, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-24-070, § 51-11C-40511, filed 12/6/16, effective 5/1/17. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-40511, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters 19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-40511, filed 2/1/13, effective 7/1/13.]