

WAC 51-50-3304 Section 3304—Site work.

3304.5.1 Fire watch during construction. Where required by the fire code official, a fire watch shall be provided during nonworking hours for new construction that exceeds 40 feet (12,192 mm) in height above the lowest adjacent grade.

EXCEPTIONS: 1. New construction that is built under the IRC.
 2. New construction less than 5 stories and 50,000 square feet per story.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-01-090, § 51-50-3304, filed 12/12/19, effective 7/1/20.]