

WAC 51-56-0900 Chapter 9—Vents.

908.2.4 Water Closet. This section is not adopted.

911.1 Circuit Vent Permitted. A maximum of eight fixtures connected to a horizontal branch drain shall be permitted to be circuit vented. Each fixture drain shall connect horizontally to the horizontal branch being circuit vented. The horizontal branch drain shall be classified as a vent from the most downstream fixture drain connection to the most upstream fixture drain connection to the horizontal branch. Given its grease-producing potential, restaurant kitchen equipment shall not be connected to a circuit vented system.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 20-02-072, § 51-56-0900, filed 12/26/19, effective 7/1/20; WSR 16-02-044, § 51-56-0900, filed 12/30/15, effective 7/1/16. Statutory Authority: RCW 19.27.074, 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-054, § 51-56-0900, filed 2/1/13, effective 7/1/13; WSR 10-03-101, § 51-56-0900, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.190, 19.27.020 and chapters 19.27 and 34.05 RCW. WSR 07-01-094, § 51-56-0900, filed 12/19/06, effective 7/1/07. Statutory Authority: RCW 19.27.031, 19.27.074. WSR 02-01-114, § 51-56-0900, filed 12/18/01, effective 7/1/02.]