

**WAC 173-360A-0550 Emergency response requirements.** (1) **Presence of operators.** While a UST facility is manned, UST system owners and operators must ensure at least one of the individuals manning the facility is a properly trained Class A, Class B, or Class C operator.

(2) **Signage.** At each UST facility, UST system owners and operators must post and maintain signage providing emergency response information. The signage must:

(a) Be posted in prominent areas of the facility that are easily visible to individuals who dispense or deliver regulated substances;

(b) Identify the location of fire extinguishers and any emergency shut-off devices at the facility; and

(c) Provide instructions on what to do in case of an emergency at the facility. At a minimum, the instructions must include the following or equivalent wording:

(Name and address of facility)

IN CASE OF FIRE, SPILL OR RELEASE

(Insert if applicable: Use emergency shut off)

Call the fire department: (911 or local fire department telephone number)

Call the facility operator: (24-hour telephone number)

[Statutory Authority: Chapter 90.76 RCW. WSR 18-15-083 (Order 16-02), § 173-360A-0550, filed 7/18/18, effective 10/1/18.]