

(Effective until March 1, 2022.)

WAC 246-215-05215 Design, construction and installation—Back-flow prevention, air gap (2009 FDA Food Code 5-202.13). An air gap between the water supply inlet and the flood level rim of the PLUMBING FIXTURE, EQUIPMENT, or nonFOOD EQUIPMENT must be at least twice the diameter of the water supply inlet and may not be less than one inch (25 mm).

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05215, filed 1/17/13, effective 5/1/13.]

(Effective March 1, 2022.)

WAC 246-215-05215 Design, construction and installation—Back-flow prevention, air gap (FDA Food Code 5-202.13). An air gap between the DRINKING WATER supply inlet and the flood level rim of the PLUMBING FIXTURES or EQUIPMENT, meet the definition of an APPROVED air gap in WAC 246-290-010.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05215, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05215, filed 1/17/13, effective 5/1/13.]