

(Effective until March 1, 2022.)

WAC 246-215-05310 Design and construction—Inspection and cleaning port, protected and secured (2009 FDA Food Code 5-302.12). If a water tank is designed with an access port for inspection and cleaning, the opening must be in the top of the tank and:

- (1) Flanged upward at least one-half inch (13 mm); and
- (2) Equipped with a port cover assembly that is:
 - (a) Provided with a gasket and a device for securing the cover in place; and
 - (b) Flanged to overlap the opening and sloped to drain.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05310, filed 1/17/13, effective 5/1/13.]

(Effective March 1, 2022.)

WAC 246-215-05310 Design and construction—Inspection and cleaning port, protected and secured (FDA Food Code 5-302.12). If a water tank is designed with an access port for inspection and cleaning, the opening must be in the top of the tank and:

- (1) Flanged upward at least one-half inch (13 mm); and
- (2) Equipped with a port cover assembly that is:
 - (a) Provided with a gasket and a device for securing the cover in place; and
 - (b) Flanged to overlap the opening and sloped to drain.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05310, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05310, filed 1/17/13, effective 5/1/13.]