

(Effective until March 1, 2022.)

WAC 246-215-05315 Design and construction—"V" type threads, use limitation (2009 FDA Food Code 5-302.13). A fitting with "V" type threads on a water tank or inlet or outlet must be allowed only when a hose is permanently attached.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 13-03-109, § 246-215-05315, filed 1/17/13, effective 5/1/13.]

(Effective March 1, 2022.)

WAC 246-215-05315 Design and construction—"V" type threads, use limitation (FDA Food Code 5-302.13). A fitting with "V" type threads on a water tank or inlet or outlet must be allowed only when a hose is permanently attached.

[Statutory Authority: RCW 43.20.050 and 43.20.145. WSR 21-01-122, § 246-215-05315, filed 12/15/20, effective 3/1/22; WSR 13-03-109, § 246-215-05315, filed 1/17/13, effective 5/1/13.]