- WAC 246-272B-06450 Sewage tanks. (1) The design engineer shall specify and the installer shall install only sewage tanks that comply with the requirements of chapter 246-272C WAC, On-site sewage system tanks, and this section.
- (2) Sewage tanks must be tested for water tightness after installation at the project site, per requirements of WAC 246-272B-05200. The department shall not issue final approval for a LOSS with a sewage tank that does not pass the water tightness test.
- (3) Sewage tanks used in proprietary treatment systems must be sized according to the manufacturer's specifications.
 - (4) Septic tanks must have:
- (a) An effluent screen with a maximum mesh size of one-eighth inch for all applications;
 - (b) The following minimum liquid volumes:
- (i) One thousand gallons per residence for LOSS treating sewage from a residential development where individual lots each have a tank;
 - (ii) Three times the daily design flow for all other LOSS.
- (5) Where proprietary treatment is used, the department may approve other septic tank sizes if justified by the manufacturer.
- (6) Sizing of a sewage tank used for hydraulic surge control or where batch treatment occurs must be justified and any effect on treatment must be addressed.
- (7) The design engineer shall size the pump chamber so there is sufficient volume, at a minimum, for:
 - (a) Routine dosing;
 - (b) Pump submergence;
 - (c) Scum and sludge storage; and
 - (d) Emergency storage.
- (8) Emergency storage must be provided in the pump chamber or in the LOSS at or before the point at which pumping will stop during a power outage, as follows:
- (a) Twenty-four hours of reserve capacity for LOSS with design flow from 3,500 up to and including 14,500 gpd; and
- (b) Twelve hours reserve capacity for LOSS with design flow above 14,500 gpd.
- (9) No reduction in pump tank reserve volume is allowed with a back-up power generator.
 - (10) Grease interceptors must have:
 - (a) A minimum volume of one thousand gallons; or
- (b) Two times the daily greywater design flow of the facility served, whichever is greater.

[Statutory Authority: RCW 70.118B.020. WSR 11-12-035, § 246-272B-06450, filed 5/25/11, effective 7/1/11.]