

**WAC 296-150C-1030 Fire-blocking.** (1) Fire-blocking must be provided in commercial coaches to cut off all concealed draft openings in all stud walls and partitions, including furred spaces at the ceiling and floor levels and at ten foot intervals both vertical and horizontal.

(2) Fire-blocking must be provided around vents, pipes, ducts, chimneys, fireplaces, and similar openings which afford a passage for fire at ceiling and floor levels, with noncombustible material.

(3) Fire blocking must be two inch nominal lumber, gypsum board, cement asbestos board, mineral fiber or other approved materials securely fastened in place.

[Statutory Authority: RCW 43.22.340, [43.22.]355, [43.22.]360, [43.22.]432, [43.22.]440 and [43.22.]480. WSR 96-21-146, § 296-150C-1030, filed 10/23/96, effective 11/25/96.]