

WAC 296-826-40045 Automatic control equipment for refrigerated storage. (1) You must install an emergency alarm to detect minimum and maximum allowable operating pressure changes.

(2) You must install an emergency alarm and shut off in the condenser system to detect excess discharge pressure caused by the failure of the cooling medium.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-826-40045, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 06-10-067, § 296-826-40045, filed 5/2/06, effective 9/1/06.]