

(Effective August 1, 2022)

WAC 246-366A-120 Restrooms and showers—Construction requirements. School officials shall:

(1) Provide shower facilities for grades nine and above for classes in physical education and for team sports. Showers must supply hot water between one hundred and one hundred twenty degrees Fahrenheit.

(2) Provide floor surfaces in shower areas that are water impervious, slip-resistant, and sloped to floor drains. Walls must be water impervious up to showerhead height. Upper walls and ceilings must have an easily cleanable surface.

(3) Locate drying areas, if provided, adjacent to showers and locker or dressing rooms. Walls and ceilings must have an easily cleanable surface and floor surfaces must be water impervious, slip-resistant, and sloped to floor drains.

(4) Provide locker or dressing rooms adjacent to showers or drying rooms. Walls and ceilings must have an easily cleanable surface. When drying areas are provided, floor surfaces in locker or dressing rooms must be appropriate for the intended use, easily cleanable and dryable to effectively inhibit mold growth. When drying areas are not provided, locker or dressing room floor surfaces must be water impervious, slip-resistant, and sloped to floor drains.

[Statutory Authority: RCW 43.20.050. WSR 10-01-174, 10-12-018, 11-10-080, 13-09-040, 15-09-070, 17-14-055, 19-14-107 and 21-14-056, § 246-366A-120, filed 12/22/09, 5/21/10, 5/3/11, 4/11/13, 4/15/15, 6/28/17, 7/2/19 and 7/1/21, effective 8/1/22.]