

**WAC 296-150V-1410 What are the electrical bonding requirements for gas piping in a conversion vendor unit or medical unit?** (1) Gas piping must not be used for an electrical ground.  
(2) The gas line must be bonded.

[Statutory Authority: Chapter 43.22 RCW. WSR 99-18-069, § 296-150V-1410, filed 8/31/99, effective 10/1/99.]