

**WAC 296-305-06513 Refueling areas.** (1) Refueling pumps, if installed, must be in accordance with the provisions of the International Fire Code and WAC 296-24-33015.

(2) Dispensing of Class 1 liquids must be as required in the International Fire Code.

(3) Spillage of oil or fuel must be properly disposed of or completely evaporated and the fuel tank cap replaced before restarting engine.

(4) Fueling areas must be posted - "NO SMOKING - STOP YOUR MOTOR."

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 18-22-116, § 296-305-06513, filed 11/6/18, effective 12/7/18. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060 and 29 C.F.R. 1910.156, Fire brigades. WSR 13-05-070, § 296-305-06513, filed 2/19/13, effective 1/1/14. Statutory Authority: RCW 49.17.010, [49.17].050 and [49.17].060. WSR 96-11-067, § 296-305-06513, filed 5/10/96, effective 1/1/97; Order 77-20, § 296-305-06513, filed 10/18/77 and Emergency Order 77-24, filed 11/17/77, effective 12/17/77.]