

WAC 296-826-40040 Separators for refrigerated storage. You must install an entrainment separator, of suitable size and design pressure, in the compressor suction line that is equipped with both of the following:

- (1) A drain valve; and
- (2) A gauging device.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-826-40040, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 06-10-067, § 296-826-40040, filed 5/2/06, effective 9/1/06.]