

(Effective until July 1, 2023)

WAC 51-50-0911 Section 911—Reserved.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 16-03-064, § 51-50-0911, filed 1/19/16, effective 7/1/16; WSR 10-03-097, § 51-50-0911, filed 1/20/10, effective 7/1/10.]

(Effective July 1, 2023)

WAC 51-50-0911 Section 911—Fire command center.

911.1.2 Separation. The *fire command center* shall be separated from the remainder of the building by not less than a one 2-hour fire barrier constructed in accordance with Section 707 or horizontal assembly constructed in accordance with Section 711, or both.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, § 51-50-0911, filed 6/14/22, effective 7/1/23; WSR 16-03-064, § 51-50-0911, filed 1/19/16, effective 7/1/16; WSR 10-03-097, § 51-50-0911, filed 1/20/10, effective 7/1/10.]