

*(Effective July 1, 2023)*

**WAC 51-54A-2404 Spray finishing.**

**2404.2.1 Prohibited enclosures for spray application operations.** Inflatable or portable enclosures shall not be used for spray application of flammable finishes.

EXCEPTION: Enclosures for the spray application of flammable finishes in marinas, dry docking areas, or construction areas shall comply with Section 2404.3.5.

**2404.3.5 Membrane enclosures.** The design, construction, protection, operation and maintenance of membrane enclosures shall be in accordance with NFPA 33.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-093, § 51-54A-2404, filed 6/14/22, effective 7/1/23.]