

WAC 296-803-50015 Meet these additional requirements when applying lockout devices. You must make sure lockout devices hold the energy-isolating device in a "safe" or "off" position.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, and 49.17.060. WSR 17-18-075, § 296-803-50015, filed 9/5/17, effective 10/6/17; WSR 04-15-105, § 296-803-50015, filed 7/20/04, effective 11/1/04.]