

**WAC 296-826-30020 Refrigerated storage.** (1) You must make sure the minimum design temperature is the same as the refrigerated temperature of the tank.

(2) You must construct and test containers, with a design pressure exceeding 15 psig, according to the Unfired Pressure Vessel Code.

(3) You must select construction materials from those listed from *API Standard 620, 4th Edition 2002, Recommended Rules for Design and Construction of Large, Welded Low Pressure Storage Tanks.*

(4) You must construct tanks with a design pressure with 15 psig or less according to *API Standard 620, 4th Edition, 2002.*

(5) You must use ASME Code as a guide in the selection of austenitic steels or nonferrous materials, if used at the design temperature.

[Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050. WSR 15-23-086, § 296-826-30020, filed 11/17/15, effective 12/18/15. Statutory Authority: RCW 49.17.010, 49.17.040, 49.17.050, 49.17.060. WSR 06-10-067, § 296-826-30020, filed 5/2/06, effective 9/1/06.]