

WAC 344-12-095 Fire hazards. Any rubbish or debris that might constitute a fire hazard in the operation of the well, tanks, separator, or other equipment shall be removed to a distance of at least 100 feet (30 meters) from the well location, tanks, and separators.

[Statutory Authority: RCW 78.52.050 and chapter 78.52 RCW. WSR 82-12-052 (Order 3, Resolution No. 7), § 344-12-095, filed 6/1/82; Rule 17, filed 3/23/60.]