

(Effective until March 15, 2024)

WAC 51-11R-40315 Section R403.2—Hot water boiler.

R403.2 Hot water boiler outdoor temperature setback. Hot water boilers that supply heat to the building through one- or two-pipe heating systems shall have an outdoor temperature setback control that lowers the boiler water temperature based on the outdoor temperature.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40315, filed 1/6/16, effective 7/1/16.]

(Effective March 15, 2024)

WAC 51-11R-40315 Section R403.2—Hot water boiler.

R403.2 Hot water boiler temperature reset. The manufacturer shall configure each gas, oil, and electric boiler (other than a boiler equipped with a tankless domestic water heating coil) with an automatic means of adjusting the water temperature supplied by the boiler to ensure incremental change of the inferred heat load will cause an incremental change in the temperature of the water supplied by the boiler. This can be accomplished with outdoor reset, indoor reset, or water temperature sensing.

[Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and chapter 19.27A RCW. WSR 23-02-060, 23-12-102, and 23-20-022, § 51-11R-40315, filed 1/3/23, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.020, 19.27A.045, 19.27A.160, and 19.27.074. WSR 16-02-127, § 51-11R-40315, filed 1/6/16, effective 7/1/16.]