

(Effective until March 15, 2024)

WAC 51-50-0509 Section 509—Incidental uses.

509.4.1.1 Type IV-B and IV-C construction. Where Table 509 specifies a fire-resistance-rated separation, mass timber elements serving as fire barriers or a horizontal assembly in Type IV-B or IV-C construction shall be separated from the interior of the incidental use with an approved thermal barrier consisting of a minimum of 1/2 inch (12.7 mm) gypsum board or a material that is tested in accordance with and meets the acceptance criteria of both the Temperature Transmission Fire Test and the Integrity Fire Test of NFPA 275.

**Table 509
Incidental Uses**

Room or Area	Separation and/or Protection
Dry type transformers over 112.5 kVA and required to be in a fire resistant room per NEC (NFPA 70) Section 450.21 (B) ¹	1 hour or provide automatic sprinkler system

¹ Dry type transformers rated over 35,000 volts and oil-insulated transformers shall be installed in a transformer vault complying with NFPA 70.

(Remainder of table unchanged)

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 19-02-038, § 51-50-0509, filed 12/26/18, effective 7/1/19. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-0509, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-0509, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-0509, filed 12/19/06, effective 7/1/07.]

(Effective March 15, 2024)

WAC 51-50-0509 Section 509—Incidental uses.

**Table 509
Incidental Uses**

Room or Area	Separation and/or Protection
Dry type transformers over 112.5 kVA and required to be in a fire resistant room per NEC (NFPA 70) Section 450.21 (B) ¹	1 hour or provide automatic sprinkler system

¹ Dry type transformers rated over 35,000 volts and oil-insulated transformers shall be installed in a transformer vault complying with NFPA 70.

(Remainder of table unchanged)

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0509, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-02-038, § 51-50-0509, filed 12/26/18, effective 7/1/19. Statutory Authority: RCW 19.27.031 and

chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-0509, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-0509, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-0509, filed 12/19/06, effective 7/1/07.]

(Effective March 16, 2024)

WAC 51-50-0509 Section 509—Incidental uses.

**Table 509.1
Incidental Uses**

Room or Area	Separation and/or Protection
Dry type transformers over 112.5 kVA and required to be in a fire resistant room per NEC (NFPA 70) Section 450.21 (B) ¹	1 hour or provide automatic sprinkler system

¹ Dry type transformers rated over 35,000 volts and oil-insulated transformers shall be installed in a transformer vault complying with NFPA 70.

(Remainder of table unchanged)

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-102, § 51-50-0509, filed 11/15/23, effective 3/16/24; WSR 22-13-094, 23-12-103, and 23-20-023, § 51-50-0509, filed 6/14/22, 6/7/23, and 9/25/23, effective 3/15/24; WSR 19-02-038, § 51-50-0509, filed 12/26/18, effective 7/1/19. Statutory Authority: RCW 19.27.031 and chapters 19.27 and 34.05 RCW. WSR 13-04-067, § 51-50-0509, filed 2/1/13, effective 7/1/13. Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 10-03-097, § 51-50-0509, filed 1/20/10, effective 7/1/10. Statutory Authority: RCW 19.27.074, 19.27.020, and chapters 70.92, 19.27, and 34.05 RCW. WSR 07-01-091, § 51-50-0509, filed 12/19/06, effective 7/1/07.]