

WAC 51-11C-405053 Table C405.4.2(1)—Interior lighting power allowances—Building area method.

**Table C405.4.2(1)
Interior Lighting Power Allowances—Building Area Method**

Building Area Type	LPD (w/ ft²)
Automotive facility	0.64
Convention center	0.64
Court house	0.79
Dining: Bar lounge/leisure	0.79
Dining: Cafeteria/fast food	0.72
Dining: Family	0.71
Dormitory	0.46
Exercise center	0.67
Fire station	0.54
Gymnasium	0.75
Health care clinic	0.70
Hospital	0.84
Hotel/motel	0.56
Library	0.83
Manufacturing facility	0.82
Motion picture theater	0.44
Multiple family	0.41
Museum	0.55
Office	0.64
Parking garage	0.14
Penitentiary	0.65
Performing arts theater	0.84
Police station	0.66
Post office	0.65
Religious building	0.67
Retail	0.84
School/university	0.70
Sports arena	0.62
Town hall	0.69
Transportation	0.50
Warehouse	0.40
Workshop	0.91

[Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapters 19.27A and 19.27 RCW. WSR 22-14-091, 23-12-101, and 23-20-021, § 51-11C-405053, filed 7/1/22, 6/7/23, and 9/25/23, effective 3/15/24. Statutory Authority: RCW 19.27A.020, 19.27A.025, 19.27A.160 and chapter 19.27 RCW. WSR 19-24-040, § 51-11C-405053, filed 11/26/19, effective 7/1/20. Statutory Authority: RCW 19.27A.025, 19.27A.160, and 19.27.074. WSR 16-03-072, § 51-11C-405053, filed 1/19/16, effective 7/1/16. Statutory Authority: RCW 19.27A.020, 19.27A.025 and chapters

19.27 and 34.05 RCW. WSR 13-04-056, § 51-11C-405053, filed 2/1/13, effective 7/1/13.]