

**WAC 51-50-0107 Section 107—Construction documents.**

**107.2 Construction documents.** Construction documents shall be in accordance with Sections 107.2.1 through 107.2.9.

**107.2.9 Nonstructural components.** Construction documents shall indicate if structural support and anchoring documentation for nonstructural components is part of the design submittal or a deferred submittal. The construction documents for nonstructural components shall at a minimum identify the following:

1. All nonstructural components required by ASCE 7 Section 13.1.3 to have an importance factor of,  $I_p$ , of 1.5.

2. All mechanical equipment, fire sprinkler equipment, electrical equipment, and other nonstructural components required by ASCE 7 Section 13.1.3 Item 1 to be operational following a seismic event that require designated seismic systems per ASCE 7 Section 13.2.2 and special inspections per Section 1705.13.4.

[Statutory Authority: RCW 19.27.031, 19.27.074, and 19.27.540. WSR 23-02-073, 23-12-103, and 23-20-023, § 51-50-0107, filed 1/4/23, 6/7/23, and 9/25/23, effective 3/15/24.]