

WAC 51-52-0602 Section 602—Plenums.

602.1 General. Supply, return, exhaust, relief and ventilation air plenums shall be limited to uninhabited crawl spaces, areas above a ceiling or below the floor, attic spaces and mechanical equipment rooms. Plenums shall be limited to one fire area. Air systems that serve multiple fire areas shall be ducted from the boundary of the fire area served directly to the air-handling equipment. Fuel-fired appliances shall not be installed within a plenum.

[Statutory Authority: RCW 19.27.031 and 19.27.074. WSR 23-23-105, § 51-52-0602, filed 11/15/23, effective 3/16/24; WSR 16-01-148, § 51-52-0602, filed 12/21/15, effective 7/1/16.]